

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F.6/DFS/MS/2025/ 181

Dated 22.04.2025

To,

Authorized Signatory,
New Delhi YMCA Tourist Hostel,
1, Jai Singh Road, New Delhi.

**Sub:-Regarding renewal of FSC in r/o New Delhi YMCA Tourist Hostel located
1, Jai Singh Road, New Delhi.**

Sir,

This has reference to your online id no. 2025031103298 date 24.03.2025, on the subject cited above. In this regard the site was inspected by the officer concerned of this department on 16/04/2025 in the presence of Sh. Vincent Officer and the following shortcomings were observed:-

1. Smoke detectors provided but non functional.
2. MOEFA found non functional.
3. Pumps provided but non functional.

In view of above shortcomings, the application for renewal of FSC is rejected. The occupancy in the building in absence of requisite fire safety arrangements shall be at risk and liability of owner /occupier. Further, statutory authority / building sanctioning authority may take necessary action as deemed fit.

Yours faithfully

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Chief Architect, New Delhi Municipal Council, Palika Kendra, New Delhi.