



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F6 /DFS/MS/School/SZ/2025/ 870

Dated: 04/12/2025

To,

The Principal,  
New Green Field School,  
Marg -22 Saket , New Delhi - 110017.

Sub: - Regarding grant of Fire Safety Certificate in r/o New Green Field School, Marg -22 Saket , New Delhi - 110017.


Sir,

This has a reference to your Outdoor Diary no. 7749 dated 03.11.2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 19/11/2025 in the presence of Mrs. Protima Parbhakar (Principal) and observed that building comprised of Ground plus Two upper floors 02 different block and following shortcomings were observed during time of inspection:

1. Hose reel hose provided but nonfunctional.
2. PA System provided but nonfunctional.
3. Fire pump of 450 LPM provided but nonfunctional.
4. Overhead tank capacity of 5000 ltr provided against the requirement of 10000 ltr.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(A.K. Malik)  
Dy. Chief Fire Officer  
Delhi Fire Service  
o/c (u)

Copy to: -

1. Director of Education, Govt. of Delhi, Old Secretariat, New Delhi-110054.