



No.F6/DFS/MS/2025/GH/162

Dated 26/03/2025

FIRE SAFETY CERTIFICATE

Certified that the M/s New Gupta Guest House located at 969-872, Gali Telyan S.P.M. Marg, Delhi-110006 comprised of Ground + 03 upper floors, Upper ground – reception + 01 hall for 5 beds, 1st floor-01 hall + 06 guest room, 2nd floor-18 guest rooms total 24 guest rooms & 02 hall with 05 beds each only), 3rd floor- owner residence owned/occupied by M/s New Gupta Guest House was granted FSC by this department vide letter No. F6/DFS/MS/GH/NDZ/2022/72 dated 02.02.2022. the premises was inspected by the officer concerned of this department on 11.03.2025 in the presence of Sh. Mannu Gupta (Manager). The building has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Residential, Sub Division-A-1 with effect from26/03/2025...for period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on26/03/2025..... at New Delhi by

(Anul Garg)
Director

Ph: 011-23414000

Copy to:-

1. The Commissioner, Municipal Corporation of Delhi, to ensure the occupancy detailed above.
2. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defense Colony New Delhi. ID No- 2025022802540 dated 28.02.25.
3. The Owner, M/s New Gupta Guest House located at 969-872, Gali Telyan S.P.M. Marg, Delhi-110006.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the MHA portal along with a copy of this Certificate, **six months** prior to its expiry".

N/35
INSPECTION REPORT

1. Name & address of the building:- : New Gupta Guest House, 969-872, Gali Telyan, SPM Marg, Delhi-110006.
2. Type of occupancy:- : Residential, Sub Division-A-1
Upper ground + 03 upper floors
Upper ground (rear side)-Reception+01 hall, (5 beds) + 02 stores,
1st floor -01 hall (5 beds) + 06 guest rooms
2nd floor- 18 guest rooms
3rd floor- Owner's residence
3. Type of case:- : Renewal
4. Details of previous FSC:- : No. F6/DFS/MS/GH/NDZ/2022/72 dated 02.02.2022.
5. Fire safety directives No.- : N/A
6. Date of inspection:- : 11.03.2025
7. Name of the inspecting officer:- : ADO (RN)
8. Name & designation of officer
From the building side:- : Mr. Mannu Gupta (Manager)
9. Year of construction:- : 2001
10. Applicant's letter No:- : online id no.2025022802540 dated 28.02.25.


S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	N/A	06 mtr.	N/A
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 Nos.	02 Nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	0.80 mtr	1.0m & .70m	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01 nos.	01 nos.	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	0.80mtr.	1.0 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	Required	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	10 Nos.	10 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	02	02	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR

7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors CO	Required	Provided	MR
	2) Location of main panel	Gr. floor	Provided*	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Gr. floor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump output	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	225 LPM	225 LPM	MR
	b) Head of pump	30 mtr.	30 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	2,500 ltr.	2,500 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A

		Required	Provided	MR
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			NA

The fire protection systems provided in the guest house building were randomly tested, checked and found functional at the time of inspection. The observations/ shortcomings issued and communicated vide this department letter of even no. F6/DFS/MS/GH/2025/SZ/62 dated: 03.02.2025 have been complied by the management.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. No. F6/DFS/MS/GH/NDZ/2022/72 dated 02.02.2022, renewal under rule 37 of the Delhi Fire Service rules 2010, is recommended.


Signature of the Inspecting Officer
Name: - C.L. Meena
Designation: - ADO (RN)

DO (ED)

17/4/25

Dy. C.S. (1002)

LVP
20/03/25

C.F.O.

24/01/2025

Director

24/01/25

ADP RN

Conf-- - P.T.O.