




GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



NO. F-6/DFS/MS/EH/2025/ 129

Dated: 20/03/2025

To

The Commissioner,
Municipal Corporation of Delhi,
8th Floor, Minto Road,
New Delhi.

Sub: - Regarding issuance of fire safety certificate in r/o M/s New Khalsa Restaurant at C-212,
Phase-II, Mayapuri Industrial Area, Delhi-110064

Sir,

This has reference with **MCD Portal ID 2025022802559 dated 28.02.2025** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 15.03.2025 in the presence of Sh. Pritam Singh to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. The first aid hose reel is not provided.
2. Internal hydrant is not provided.
3. Terrace level fire fighting pump capacity 450 LPM is not provided
4. Overhead tank capacity 20,000 liters not provided.
5. Exit signages are not provided.
6. Fire Extinguishers are not provided.
7. MOEFA is not provided.
8. Drawing of the building is not provided in CAF.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

ok 4

Copy to:-

1. Sh. Pritam Singh,
G-112, First Floor, G- Block,
Vikas Puri, Tilak Nagar,
Delhi-110018