

c121



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/School/2026/EZ/145

Dated: 10 / 09 / 2026

FIRE SAFETY CERTIFICATE

Certified that the **New Krishna Public School** at A-1, Prakash Vihar, Karawal Nagar, Delhi-110094, comprised of ground plus one upper floor only, owned/occupied by New Krishna Public School, was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2023/NDZ/369 Dt 29/05/2023. The premise was re-inspected by the officer concerned of this department on 20/08/2026 in the presence of Sh. Braham Prakash (Manager) and found that the said building/premises have complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by the Director of Education and that the building is fit for occupancy class "Educational Group-B" with effect from 10 / 09 / 2026 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010.

Issued on 10 / 09 / 2026 at New Delhi by


31/9/26

(Dr. S.K. Tomar)
Chief Fire Officer
Delhi Fire Service

01/08

Copy to: -

1. The Manager, New Krishna Public School at A-1, Prakash Vihar, Karawal Nagar, Delhi-110094.
2. The Deputy Director of Education, Govt. of National Capital Territory of Delhi, B-Block, Yamuna Vihar, Delhi-110053.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection.
3. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire-fighting system.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, prior to its expiry.
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

N-13

INSPECTION REPORT				
1.	Name & address of the building	New Krishna Public School located at A-1, Prakash Vihar, Karawal Nagar, Delhi-110094		
2.	Type of Occupancy	Educational, Group 'B-1'		
3.	Building Comprised of	Ground + 01 upper floors		
4.	Type of Case	Renewal		
5.	Details of previous FSC No.	F6/DFS/MS/School/2023/NDZ/369 Dt 29/05/2023		
6.	Fire safety directives letter No.	DOE Circular No. 3298 to 3398 dated 01.03.2011		
7.	Date of inspection	20/08/2026		
8.	Name of the Inspecting Officer	ADO (Gokalpur)		
9.	Name and designation of Officer from the building side	Sh. Braham Prakash (Manager)		
10.	Year of Construction	1998		
11.	Applicant's letter No./Online Appn.	No. 52026041502247		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old FSC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	Road width	6.0 mtr	18 mtr	MR
	Gate width	N/A	N/A	N/A
	Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	Upper floors	01 No.	02 Nos	MR
	Basements	N/A	N/A	N/A
	b. Width of staircases			
	Upper floors	1.50 mtr	1.45m & 1.06m	MR
	Basements	N/A	N/A	(Old case) N/A
	c. Protection of exits			
	Fire check door	N/A	N/A	N/A
	Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of Corridor	1.0 m	1.0 m	MR
	f. Door Size	1.0 m	1.0 m	MR
3.	Compartmentation			
	Fire check door	N/A	N/A	N/A
	Sealing of electrical shafts	N/A	N/A	N/A
	Fire Rating of shaft door	N/A	N/A	N/A
	Water Curtain	N/A	N/A	N/A
	Fire Dampers	N/A	N/A	N/A
4.	Smoke Managements System			
	Basement.	N/A	N/A	N/A
	Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	Total numbers	04 Nos	06 Nos	MR
	Types	ABC & CO ₂	Provided	MR
	ISI marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	Total numbers on each floor	N/A	N/A	N/A
	Length of hose reel hose	N/A	N/A	N/A
	Nozzle diameter	N/A	N/A	N/A

88

7.	Automatic fire detection and alarming system.			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper floors.	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants.	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water storage for firefighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15.	Exit signage	N/A	N/A	N/A
16.	Provision of lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A

N-15

19.	Fire Control Room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building/premises were checked, tested at random and **found functional at the time of inspection.**

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety as required under DOE Circular No. 3298 to 3398 Dated 01/03/2011, the fire safety certificate issued vide letter No. F6/DFS/MS/School/2023/NDZ/369 Dt 29/05/2023, **renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.**

Accordingly, **DFA is put up for approval and signature please.**

Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (Gokalpur)

DO (ED)

CFO (East Zone)

Principal Director

CFO (CZ)

ADO/GP

Sir, F.T letter is prtnup for your sing. pl

CFO (ECN)

ms

ADO/GP

ADO/GP
08.03.26