

C/25

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F6/DFS/MS/School/2025/SZ/ 612

Dated: 07/08/2025

To,

The Manager,  
New Merry Public School,  
A-6, Sish Ram Park,  
Uttam Nagar, New Delhi- 110059.

**Sub: -Regarding renewal of "FSC" from fire safety point of view in r/o New Merry Public School at A-6, Sish Ram Park, Uttam Nagar, New Delhi- 110059.**


Sir,

Please refer to your letter No. NM/07/25/107, dated Nil, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the school building on dated 21.07.2025 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh. Deepak Lamba (Manager) of the school was present and it was observed that the previously, this department issued FSC vide letter No. F.6/DFS/MS/School/2022/SZ/225 dated 02.03.2022 for ground plus one upper floor only but now school management running school at second & third floor also, and have following shortcomings:-

1. One of the staircases having width of 1.0 m from ground floor to 1<sup>st</sup> floor & second staircase of 1.0 m from ground floor to terrace found provided against requirement of two staircases with width of 1.50 m each from ground floor to terrace level.
2. Hose reels found not provided.
3. Terrace fire pump of 180 LPM found provided against requirement of 450 LPM.
4. Overhead water storage tank capacity of 2,000 ltrs. found provided against requirement capacity of 10,000 ltrs.
5. Exit signage's are found not provided.

In view of the above, renewal of 'Fire Safety Certificate' cannot be granted at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for taking further necessary action in this matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the school management.

Yours faithfully

  
(Virendra Singh)  
Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.