



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/Hospital/2025/SZ/ 406

Dated: 21/08/2025

To

Sh. Satesh Kumar,
ASO (Fire Safety),
Administrative Block,
AIIMS, New Delhi-110029

Sub: **Renewal of Fire Safety Certificate in r/o New OPD Block (RAK), AIIMS Complex, Ansari Nagar, New Delhi-110029**



Sir,

This is with reference to the email received from Id: satesh@aiims.gov.in dated 27/06/2025, on the subject cited above. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department on dated 30/07/2025 to see the performance of fire protection measure in your presence. **During the inspection, the shortcomings observed are as below.**

1. Smoke exhaust system in basement found non-functional.
2. First Aid hose-reel hose system found leaking at some locations.
3. Manual call points system was under repair.
4. Automatic sprinkler system needs to be extended in left out area in basement.
5. Exit signage's found removed at some locations.

In view of the above non-compliance, the application for **renewal of fire safety certificate cannot be considered at this stage**. You are advised to rectify the above shortcomings under intimation to this department for further action in the matter.

Yours faithfully,


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service


Copy to: -

1. The Executive Engineer (C)-III, All India Institute of Medical Science, Ansari Nagar, New Delhi-110029