



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI- 110001



No. F.6/DFS/MS/School/2025/SZ/ 1083

Dated: 02/09/2025

FIRE SAFETY CERTIFICATE

Certified that the New Ring Midways Public School at E-109-0113, Nanhey Park, Uttam Nagar, New Delhi- 110059, comprised of ground floor plus two upper floors, owned/occupied by New Ring Midways Public School, was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2018/SZ/232 dated 09.02.2018. The school building was re-inspected by the officer concerned of this department on dated 18.08.2025 in the presence of Sh. Mahesh (Principal) of the school, and found that the school building have complied the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises (ground plus two upper floors) is fit for occupancy class "Educational Building" w.e.f. 02/09/25 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 02/09/25 at New Delhi by.


(Virendra Singh)
Chief Fire Officer


Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054
2. The Manager, New Ring Midways Public School at E-109-0113, Nanhey Park, Uttam Nagar, New Delhi- 110059.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/17

INSPECTION REPORT

1. Name & address of the building : New Ring Midways Public School at E-109, Nanhey Park, Uttam Nagar, New Delhi-110059
2. Building is comprised of : Two Blocks Old block having G+2 upper floors & New Block having G+3 upper floors.
3. Type of Occupancy : 'Educational Building' (School running at Old block only)
4. Type of Case : Renewal
5. Details of Previous FSC letter : F6/DFS/MS/School/2018/SZ/232 dated 09/02/2018
6. Fire Safety direction letter No : N/A
7. Date of Inspection : 18.08.2025
8. Name of the Inspecting officers : ADO R.K. Yadav
9. Name and designation of Officer:
From the building side : Sh. Mahesh (Manager)
10. Year of Construction : Old Block Before 2010 & New Block 2020
11. Applicant's letter No : NRPMS/2025 dated 04.08.2025

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width 	06 m.	Provided	MR
	<ul style="list-style-type: none"> Gate width 	4.5 m	Direct accessible from road	N/A
	<ul style="list-style-type: none"> Width of internal road 	N/A	N/A	N/A
2.	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> Upper Floor 	02 Nos.	2 Nos.	MR
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> Upper Floor 	1.5 & 0.75 m in Old Blk	1.25 m each in old blk	MR
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pressurization 	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	02 Nos.	Provided	MR
	e. Width of Corridor	1.5 M	Provided	MR
	f. Door Size	1.0 m	1.0 m	MR
3.	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Sealing of electrical shafts 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fire rating of shaft door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Water curtain 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fire Dampers 	N/A	N/A	N/A
4.	Smoke Management System.			
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Upper floor 	Required	Natural Ventilation	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	15 nos.	Provided	MR
	<ul style="list-style-type: none"> Types 	ABC /CO ₂	ABC /CO ₂	MR
	<ul style="list-style-type: none"> IS marking 	IS I marked	ISI marked	MR


6	First-aid-Hose Reels			
	• Total numbers of each floor	01 No	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	Provided	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the Pump	40 M	40 m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 ltr	Provided	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A



The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Note: - As per Affidavit submitted by the school management (placed at C-) that the school compound comprises two separate buildings. Old block comprised of ground plus two upper floors and New Block comprised of ground plus three upper floors but school running at Old Block (G+2 upper floors) only. The New Block building (G+3 upper floors) is not being used for any educational activity, nor has it ever been used for such purposes and not be used for educational purpose in the future either.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/School/2018/SZ/232 dated 09/02/2018 is recommended to be renewed under rule 37, of the Delhi Fire Service Rules, 2010.


 Signature of Inspecting Officer
 Name: - R.K. Yadav
 Designation: - ADO (JKP)

DO (South West)


 20/8/25
 C.F.O. / 
 22/8/2025
 Principal Director

ADO (JKP)


 C.F.O. / 
 28/08/25