

C/24

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI -110001


No.F6/DFS/MS/NDZ/ Hosp/2025/ 413

Dated 07/08/2025

FIRE SAFETY CERTIFICATE

Certified that the New Special Ward Block at LNJP Hospital, New Delhi comprised of Ground + 03 Upper floors owned/occupied by LNJP Hospital was earlier granted FSC by this department vide letter No.F6/DFS/MS/NDZ/Hosp/2021/471 dated 27/09/2021. Now the premises was reinspected by the officers concerned of Delhi Fire Service on dated 21.07.25 in the presence of Sh. Manish AE (E) & Sh. Rohit JE (E), PWD and found that the building has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Institutional Building with effect from 07/08/2025 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010 printed below.

Issued 07/08/2025 at New Delhi by.


6/8/2025
(Virendra Singh)
Chief Fire Officer
Delhi Fire Officer

Copy to:-

1. The Medical Superintendent, LNJP Hospital, New Delhi.
2. The Assistant Engineer (E), HC-1, Health Maint. Elect. Divn. (Central), L.N.J.P. Hospital, New Delhi - 110002.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
5. Any deviation w.r.t. construction, electric installation, etc. shall be verified by the concerned building sanctioning authority.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape such as corridor, staircase, etc shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : New Special Ward Block at LNJP Hospital,
New Delhi
2. Type of occupancy : Institutional Building
Ground + 03 Upper floors
3. Type of case:- : Renewal
4. Details of previous FSC : No.F6/DFS/MS/NDZ/Hosp/2021/471 dated
27/09/2021.
5. Fire safety directives No. : N/A
6. Date of inspection:- 21/07/25
7. Name of the inspecting officer :Sh. Rajinder Atwal DO/CD,
Sh. Ravinder Singh ADO/CC
8. Name & designation of officer
From the building side Sh. Manish AE (E) & Sh. Rohit JE (E), PWD
9. Year of construction : 2002
10. Applicant's letter No mail id aeehmed2@gmail.com dated 25.06.2025
old case (renewal)

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Approach to Building			
	1) Road width	06 mtr.	15 mtr.	MR
	2) Gate width	6.0 mtr.	6.0 mtr.	MR
	3) Width of internal road	N/A	6.0 mtr. Road front & side	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 No.	02 No.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	2 mtr.	2 mtr.	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	2.2 mtr.	2.2 mtr.	MR(old case)
	F. Door size	2.0 mtr.	2.0 mtr.	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	Required	Provided	MR
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	50 Nos.	50 Nos.	MR
	2) Types	ABC & CO2	ABC, CO2 &	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			

2/15

	1) Total number of each floor	02	02	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm.	5 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Required	Provided	MR
	2) Location of main panel	Gr. Floor	Provided	MR
	3) Location of repeater panel	Required	Provided	MR
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Gr. Floor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	1) Size of riser/down-comer	150 MM	150 MM	MR
	2) Number of hydrants per floor	02	02	MR
	3) Hose box each floor	02	02	MR
12.	Yard Hydrants			
	1) Total number of hydrants	02	02	MR
	2) Hose box	02	02	MR
13.	Pumping Arrangement	Common fire pump of main	Building	
	1) Ground level			
	a) Discharge of main pump	2850 LPM	2850 LPM	MR
	b) Head of main pump	70 mtr.	70 mtr.	MR
	c) Number of main pump	02	02	MR
	d) Jockey pump out put (2 Nos.)	180 LPM	180 LPM	MR
	e) Jockey pump head	70 mtr.	70 mtr.	MR
	f) Stand by pump output	2850 LPM	2850 LPM	MR
	g) Stand by pump head	70 mtr.	70 mtr.	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting (U/G tank Common)			
	1) Under ground tank capacity	1,00,000 ltr.	2,00,000 ltr.	MR

K/16

	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	20,000l	20,000l	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	N/A	Provided	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	Provided	N/A
	d) Battery backup	N/A	Provided	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules if agreed, we may renew the FSC issued vide letter no. F6/DFS/MS/NDZ/Hosp/2021/471 dated 27/09/2021, under rule 35 of the Delhi Fire Service rules 2010, is recommended for approval.

Signature of the inspecting officer

Signature of the Inspecting Officer

Name: - Rajinder Atwal
Designation: - DO (CD)

Name: Ravinder Singh
Designation: ADO (CC)

Dy. C.F.O. (no 2)
Lr P
28/07

C.F.O.

4/8/2025

Principal Director

CFO to Secy.

24/08/25