

C-60

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/School/2025/687

Dated: 25/08/2025

To

The Principal,  
New Sun Ideal Public School,  
T-505, Chamelian Road,  
Delhi-110006.

**Sub: Regarding Renewal of FSC in r/o New Sun Ideal Public School located at T-505,  
Chamelian Road, Delhi-110006.**


Sir,

This has reference to your letter no. nil dated 07.07.2025, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 05.08.2025 in the presence of Mr. Rajkumar and the following shortcomings are observed.

1. Hose reel & pump found non functional.
2. Overhead tank 2500 ltr provided against the provision of 5,000 ltr.

In view of above, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully

  
(Virendra Singh)  
Chief Fire Officer  
Delhi Fire Service

Copy to:-

The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.