

cl/101

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2025/SZ/368

Dated 08/08/2025

To,

The Assistant Engineer (E)
Sub Div.3 Judiciary Electrical Division-I,
PWD, District Court Saket,
New Delhi-110017

Sub: Regarding issuance of Fire Safety Certificate in r/o Newly Temporary Court Block
in Saket Court Complex, New Delhi.


Sir,

This has reference with your letter F.23(3)AE(E)Div.M-3/J/Elec./Div-1/PWD/372 Dated 08.07.2025 on the subject cited above received from E.E (E) PWD. In this regard, it is informed that the premise have been visited by concerned officer of this department on 17/07/2025 in the presence of Mr. Deepak Kumar (JE/Elect.) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. The dedicated fire Fighting pumps has not been installed yet, as per the condition listed at s.no 7 in the FSC issued and communicated by this department vide letter of even no 327 dated 26/07/2022.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(VIRENDRA SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to:

1. Hon'ble Principal District and Session Judge Saket Court for information please.