

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



Dated: 16/05/2025

E6/DFS/MS/2025/School/ 404

To

The Principal
Nigam Pratibha Kanya Vidyalaya,
Burari Village, Delhi-110084.

Sub:- Regarding issuance of fire safety certificate in r/o Nigam Pratibha Kanya Vidyalaya
(School ID No-1253026) at Burari Village, Delhi-110084

Sir,

Please refer to your letter no-nil dated: 09/04/2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was inspected by the officer concerned of this department on 06/05/2025 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of 03 blocks, ground & 02 upper floors each block only. At the time of inspection Smt. Neeru Khatri (Principal) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. Hose reel hose is provided in each blocks but found not functional and all nozzle is missing.
2. Terrace level fire pump capacity of 450 LPM is provided in each blocks but found not functional.
3. Overhead fire water tank capacity of 5,000 ltr is provided in each blocks but found empty.
4. Exit & floor signage's is not provided at strategical location in the school premises.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Dy. Director, Education Department, Civil Line Zone, 16 Rajpura Road, Delhi.