

c/15

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No. F6/DFS/MS/School/2025/ 311

Dated: 02/05/2025

To

The Head of School,
Nigam Pratibha School,
J.J, Shadi Pur-I, Pandav Nagar,
New Delhi-08.

Sub: Regarding issuance of FSC in r/o Nigam Pratibha School, J.J, Shadi Pur-I, Pandav Nagar, New Delhi-08.

Sir,

This has reference to your letter no. nil dated nil & DFS diary no. 14787 dated 21.03.2025, on the subject cited above. In this regard, it is to inform you that the site was visited by officer concerned of this department on 28.04.2025 in the presence of **Principal** and following shortcomings are observed.

1. Alternate Staircase of .75 meter is not provided in old block .
2. Hose reel & pump of 450 LPM is not provided.
3. Over head tank of 10,000 liter is not provided

In view of above, fire safety certificate (FSC) cannot be issued at this stage. Therefore, you are requested to rectify the above shortcomings at the earliest for further consideration in the matter.

Yours faithfully,

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.