



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001



No. F.6/DFS/MS/School/2025/NDZ/ 321

Dated 02/05/2025

To,

The Principal,  
Nigam Pratibha Vidyalaya  
Marginal Bandh Old -II, New Seelampur,  
Delhi-110053.

Sub: - Regarding Renewal of Fire Safety Certificate r/o Nigam Pratibha Vidyalaya at Marginal Bandh Old -II, New Seelampur, Delhi-110053.

Sir,

With reference to your Outdoor Diary No. 14676 dated 19/03/2025 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection on dated 23/04/2025 of the above mentioned School from fire safety point of view in presence of the Mr. Ashok Kumar Sharma, (Principal). The building comprised of ground plus two upper floors only. Following shortcomings were observed during the time of inspection.

1. An additional staircase of width 0.75 meter shall be required.
2. First Aid Hose reels provided but not functional.
3. Fire pump having 450 lpm head 40 meters head provided but not functional.
4. Exit signs are required to be provided in the school building at all exits.

In view of the above, the building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to rectify the above mentioned shortcomings under intimation to this office for further course of action.

Yours faithfully

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

The Dy. Director of Education, MCD

Udyog Sadan, Plot No. 419, FIE, Patparganj Ind. Area, Delhi- 110092