



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

DEA
30/7/25
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/School/NDZ/2025/ 229

Dated: 17/04/2025

To,

The Principal,
Nigam Pratibha Vidyalaya (Co-ed)
Kalyanpuri 05 Block,
Delhi - 110094.

Subject: - Regarding grant of Fire Safety Certificate in r/o Nigam Pratibha Vidyalaya (Co-ed) located at Kalyanpuri 05 Block, Delhi – 110094.

Sir,

This has a reference to your Outdoor Diary No. 14604 dated 18/03/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 07/04/2025 in the presence of Mr. Satish Kumar Bhati (Principal) and observed that building comprised of ground plus two upper floors.

Following shortcomings were observed during time of inspection:

1. First-Aid-Hose Reel not provided.
2. Terrace level fire pump capacity of 450 LPM not provided.
3. Overhead tank of capacity 10,000 liters not provided.
4. Exit & floors Signage's not provided at strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Director of Education, East Delhi Municipal Corporation, 419, Udyog Sadan, Patparganj Industrial Area, Delhi - 110092.