




GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

c/04



No: F.6/DFS/MS/School/2025/WZ/ 271

Dated: 23/04/2025

To,

The Principal,
Nigam Pratibha Co-ed Vidyalaya,
E Block, Shakurpur,
Delhi-110034.

Sub: - Regarding issuance of Fire Safety Certificate in r/o Nigam Pratibha Co-ed Vidyalaya, E Block, Shakurpur, Delhi- 110034.

Sir,

This has reference to your email id dated 07.03.2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 17.04.2025 to see the compliance of the requisite fire safety measures. Smt. Poonam Gupta (Principal) was present at the time of inspection.

During the course of inspection it was observed that school building is comprised of 04 Blocks, 02 Blocks (Ground plus one upper floor) & 02 Blocks (Ground floor only). Your request for issuance of FSC is rejected due to the following shortcomings:-

1. Exit signage's are not provided.
2. Electrical panel installed under the staircase has to be removed to a safer place or been segregated.
3. Electrical meter installed inside the class room has to be removed.

You are advised to rectify the above-mentioned shortcomings under intimation to this department.

Yours Faithfully

(Atul Garg)
Director

Ph. 011-23414000

Copy to:-

1. Director of Education, MCD, Civic Centre, New Delhi.

21/48