

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No F 6 / DFS / MS / 2025 /School/WZ/645

Dated 13 05 2025

FIRE SAFETY CERTIFICATE

Certified that the Nigam Pratibha Vidyalaya (Girls) located at Bankner, Delhi-110040 comprised of Ground and First floor was issued FSC by this department vide letter No F6 /DFS/MS/2022/School/WZ/326 dated 29.03.2022. The premises was re-inspected by the officer concerned of this department on 29.04.2025 in the presence of Smt. Kavita (In-charge), and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/premise is fit for occupancy Group B Educational with effect from .13.102.2025... for a period of three years, subject to compliance of the conditions mentioned below:

Issued on ... 31.05. 2025 at New Delhi by

Director

Ph. 011-23414000

Copy to:-

1. The Director, Education, Government of NCT of Delhi. Old Sect. Delhi-110054

2. Nigam Pratibha Vidyalaya (Girls) located at Bankner, Delhi-110040.

Conditions for the validity of Fire Safety Certificate:

- 1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
- 2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3. The trained fire fighting staff should be available round the clock.
- 4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
- 6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
- 7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
- 8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.
- 9. Electric Panel and electric meter under the staircase must be removed or been segregated within a period of three months from the date of issuance of the Fire Safety Certificate. Failing to do so the Fire Safety Certificate will be null and void.

INSPECTION REPORT

Nigam Pratibha Vidyalaya (Girls) located at Bankner, Delhi- 110040. 1. Name & address of the building:

Educational

Ground plus First floor

Renewal

2. Type of Occupancy :
3. Building Comprised of :
4. Type of Case :
5. Details of Previous NOC :
6. Fire Safety directives letter No : F6/DFS/MS/2022/School/WZ/236 dated 29/03/2022 DOE circular No. 3298-3398 dated 01/03/2011

7. Date of inspection 29/04/2025

8. Name of Inspecting Officer R.K.Sinha, ADO (BW)

9. Name and designation of officers

From the building side Smt. Kavita (In-charge)

10. Year of Construction 1994

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE Requirement	Provided at site	Remarks MR/NMR			
1.	Access to building	- Additional		1/1101/11/11			
	Road width	6 m	Provided	MR			
	Gate width	4.5 m	3 m	MR(old case)			
	Width of internal road	NA	NA	NA			
2.	Number, Width, Type & Arrangement of Exits						
1	a. Number of staircases						
	Upper Floors	01	02	MR			
	Basements	NA	NA	NA			
	b. Width of staircases	NA.	Sacina agine w				
	Upper Floor	1.50 m each	Provided	MR			
	Basements	NA	NA	NA			
	c. Protection of exits		A PART OF THE PART OF THE	# T			
	Fire check door	NA	NA NA	NA			
	Pressurization	NA	NA	NA			
	d. No. of continuous staircases to terrace	NA	NA	NA			
	e. Width of Corridor	NA	NA	NA			
	f. Door Size	-1 m	Provided with door fitting	MR(old case)			
3.	Compartmentation						
	Fire check door	NA	NA I	NA			
		NA	NA NA	NA			
	Sealing of electrical shafts File Poting of the Adopt	NA	NA NA	NA NA			
	Fire Rating of shaft door Water Curtain	NA NA	NA NA	NA NA			
		NA NA	NA NA				
4.	• Fire Dampers NA NA NA Smoke Management System						
2.00							
	Basements	NA	NA	NA			
	Upper floors	Required	Naturally Ventilated	MR			
5.	Fire Extinguishers						
	Total numbers	06	Provided	MR			
	Types	ABC Type	Provided	MR			
	IS marking	Required	Provided	MR			
6.	First-Aid Hose Reels	NA	27.7				
	Total numbers on each floor Length of hose reel hose	NA NA	NA NA	NA			
	Nozzle diameter		NA NA	NA			
	• NOZZIE diameter	NA	NA	NA			
7.	Automatic fire detection and alarming system						
	Type of detectors	NA	NA	NA			
	 Location of Main Panel 	NA	NA	NA			
	 Location of Repeater Panel 	NA	NA	NA			
	Alternate source of power	NA	NA NA	NA			
	Hooters' Location	NA		SEED IN SE			
			NA	NA			

		1122
100		٦
AI	L	

		N-23			
	Lyonn	NA	NA	NA NA	
8. 9.	MOEFA Public Address System	NA NA	NA	NA .	
		u S			
10.	Automatic Sprinkler System	9.1		NA NA	
_	Basement	NA	NA NA	NA	
	Ground Floor	NA	NA NA	NA	
	Sprinkler above false ceiling	NA	NA	NE STEE	
11.	Internal Hydrants	Light C			
	61 61 41	NA	NA	NA	
	Size of riser/down-comer Number of hydrants per floor	NA NA	NA	NA NA	
	Hose Box	NA	NA	NA	
12.	Yard Hydrants				
			NA	NA	
	Total number of hydrants	NA NA	NA NA	NA -	
13.	Hose Box Pumping Arrangements	INA			
13.					
	Ground Level	1 4 5 A 1 A 1 A 1 A 1 A 1	NA	NA	
	➤ Discharge of main Pump	NA NA	NA NA	NA NA	
	➤ Head of Main pump	NA	IVA		
	> Number of main pumps	NA	NA	NA	
	➤ Jockey Pump out put	NA	NA	NA	
	Jockey pump head	NA	NA	NA	
	> Standby Pump out put	NA	NA	NA	
	> Standby Pump Head	NA	NA NA	NA NA	
	➤ Auto Starting/Manual Stopping	NA	NA	NA	
	➤ Pump House Access	NA	NA	NA	
	Terrace level	15-15-1	p p	and the second	
	➤ Discharge of pump	NA	NA	NA	
		NA NA	NA NA	NA NA	
	➤ Head of the pump	en Lob	Sire and the		
	> Power Supply	NA	NA	NA	
14.	➤ Auto Starting of pump Captive Water Storage for fire fighting	NA	NA	NA	
3-44					
	Underground tank capacity	NA	NA	NA	
	> Draw-off connection > Fire service inlet	NA	NA	NA	
	> Access to tank	NA NA	NA NA	NA	
	Overhead Tank capacity	NA NA	NA	NA	
15.	Exit Signage.	Required	NA Provided	NA	
16.	Provision of Lifts.	Required	Provided	MR	
17.					
	Pressurization of Lift Shaft	NA	NA	NA	
	Pressurization of Lift lobby	NA	NA	NA NA	
	Communication In lift Car	NA	NA	NA NA	
	Fireman's Grounding Switch	NA	NA		
	Lift Signage	NA	NA	NA	
	Standby power supply	NA	NA NA	NA	
18.	Refuge Area.	717	IVA .	NA	
	> Total Area				
	> Location	NA	NA	NA	
	Location	NA		INM	

Detector System Panel NA NA NA Flow Switch Panel NA NA NA PA System Panel NA NA NA Battery backup NA NA NA **Building Floor Plans** NA NA NA Special Fire Protection System for 20. NA Protection of special Risks, if any: NA NA

> The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Note: Electric meter and electrical panel found installed under the staircase which have to

be removed to a safer place or been segregated.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under DOE circular no. 3298-3398 dated 01/03/2011, it is recommended to renew the Fire Safety Certificate issued vide letter number F6/DFS/MS/2022/School/WZ/326 dated 29/03/2022.

> Signature of Inspecting Officer Name: Rajeev Kumar Sinha Designation :ADO/B.W.

05 05 1202