

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001


No.F6/DFS/MS/School/NDZ/2025/ 1216

Date- 30/09/2025

FIRE SAFETY CERTIFICATE

Certified that the Nigam Pratibha Vidyalaya located at Sunder Nanhi, Dariba, Chandni Chowk, Delhi - 110006, comprised of Ground floor + one upper floor was granted FSC by this department vide letter no.F6/DFS/MS/School/NDZ/2022/926 dated 30.08.2022. The premises was re-inspected by the officer concerned of this department on 23.09.2025 in the presence of Mrs. Shivani Jain (Principal) and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 01.03.2011 that the building is fit for occupancy (Class B) "Educational Building" with effect from 30.09.2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to conditions under rule 38 of Delhi Fire service Rules, 2010 printed below.

Issued on 30.09.2025 at New Delhi by


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service
dtc 30/9/25

Copy to:-

1. The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Principal, Nigam Pratibha Vidyalaya at Sunder Nanhi, Dariba, Chandni Chowk, Delhi- 06.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

N/11
INSPECTION REPORT

1	Name and address of the building:	Nigam Pratibha Vidyalaya at Sunder Nanhi, Dariba Chandni Chowk, Delhi - 110006.
2	Type of occupancy with details of floors:	Educational Building (Group -B), Ground + 01 upper floor
3	Type of case:	Renewal case (Old Case)
4	Details of previous FSC:	F6/DFS/MS/School/NDZ/2022/926 dated 30.08.2022
5	Fire safety directives no.:	NA
6	Date of inspection:	23.09.2025
7	Name of the inspecting officer:	ADO (SPM)
8	Name and designation of the officer from the building side:	Mrs. Shivani Jain (Principal)
9	Year of construction:	1933
10	Reference letter no.:	Outdoor diary no. 5100 dated 21.08.2025 & email dated 21.08.2025

S. No	Minimum Standards on fire Prevention and fire safety requirements U/R 33		Requirements/ Existing fire safety arrangements	Provide at site	Remarks MR/NM R
1	Access to Building				
	A	Road width	06 mtrs.	One hose length 30 mtr. away from 06 mtr.	MR
	B	Gate width	NA	NA	NA
	C	Width of internal roads	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits				
	A	No. of Staircase:			
		a) Upper floor	02 nos.	02 nos.	MR
		b) Basements	NA	NA	NA
	B	Width of the Staircase:			
		a) Upper floor	1.5 mtr.	0.90 mtr. & 0.75 mtr.	MR
		b) Basements	NA	NA	NA
	C	Protection of Exits			
		a) Fire check door	NA	NA	NA
		b) Pressurization	NA	NA	NA
	D	No. of continuous staircase to terrace:			NA
	F	Width of the corridor	1.5 mtr.	1.5 mtr.	MR
	E	Door size	1 mtr.	Open arch	MR
3	Compartmentation:				
	A	Fire check doors	NA	NA	NA
	B	Sealing of electrical shafts	NA	NA	NA
	C	Fire rating of shaft doors	NA	NA	NA
	D	Water curtain	NA	NA	NA
	E	Fire dampers	NA	NA	NA
4	Smoke management System:				
	A	Basements	NA	NA	NA
	B	Upper floors	NA	NA	NA
5	Fire extinguishers				
	A	Total numbers	04 nos.	04 nos.	MR
	B	Types	Co2 & ABC	Provided	MR
	C	ISI marking	Required	Provided	MR

6	First Aid Hose reel				
	A	Total no. at each floor	NA	NA	NA
	B	Length of Hose Reel	NA	NA	NA
	C	Nozzle diameter	NA	NA	NA
7	Automatic Fire Detection and Alarm System (ADAS)				
	A	Type of Detectors	NA	NA	NA
	B	Location of main Panel	NA	NA	NA
	C	Location of Repeater Panel	NA	NA	NA
	D	Alternate power Source	NA	NA	NA
	E	Hooter's location	NA	NA	NA
8	MOEFA		NA	NA	NA
9	Public Address System		NA	NA	NA
10	Automatic Sprinkler System				
	A	Basement	NA	NA	NA
	B	Upper Floor	NA	NA	NA
	C	Sprinklers above false ceiling	NA	NA	NA
11	Internal hydrants				
	A	Size of the riser/down comer	NA	NA	NA
	B	No. Of hydrants per floor	NA	NA	NA
	C	Hose box	NA	NA	NA
12	Yard Hydrants				
	A	Total no. of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
13	Pumping arrangements				
	A	Ground Level			
		a) Discharge of main pump	NA	NA	NA
		b) Head of main pump	NA	NA	NA
		c) Number of main pump	NA	NA	NA
		d) Discharge of jockey pump	NA	NA	NA
		e) Head of jockey pump	NA	NA	NA
		f) Discharge of Standby pump	NA	NA	NA
		g) Head of Standby pump	NA	NA	NA
		h) Auto starting/ manual stopping	NA	NA	NA
	B	Terrace Level			
		a) Discharge of terrace pump	NA	NA	NA
		b) Head of terrace pump	NA	NA	NA
		c) Alternate power supply	NA	NA	NA
		d) Auto starting of pump	NA	NA	NA
14	Captive Water Storage for Fire Fighting				
	A	Underground tank capacity	NA	NA	NA
	B	Draw off connection	NA	NA	NA
	C	Fire Service Inlet	NA	NA	NA
	E	Access to tank	NA	NA	NA
	D	Overhead tank capacity	NA	NA	NA
15	Exit Signage		NA	NA	NA
16	Provision of lift				
	A	Pressurization of lift shaft	NA	NA	NA
	B	Pressurization of lift lobby	NA	NA	NA
	C	Communication in lift car	NA	NA	NA
	D	Fireman switch	NA	NA	NA
	E	Lift signage	NA	NA	NA
17	Standby Power Supply		NA	NA	NA

18	Refuge Area			
	A	location	NA	NA NA
	B	Total area	NA	NA NA
19	Fire Control Room			
	A	Fire Detection System panel	NA	NA NA
	B	Flow switch panel	NA	NA NA
	C	P A system panel	NA	NA NA
	D	Battery backup	NA	NA NA
	E	Building floor plan	NA	NA NA
20	Special Fire Protection for special risk if any:			Fire Buckets

The fire protection system provided in the school were tested, checked and random and found functional at the time of inspection.

Keeping in view of deemed compliance of the minimum standards on fire prevention and fire safety required under the Director Education Circular No. 3298-3398 dated 01.03.2011, the FSC issued vide letter no. F6/DFS/MS/School/NDZ/2022/926 dated 30.08.2022 **renewal** under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Sumit Kumar
24/09/2025
Signature of the Inspecting Officer
Name Sumit Kumar
Designation ADO (SPM)

DO (CD)

24/9/25
Dy. C.F.O. (NDZ)
24/09/25
CF.O
25/9/2025

Principal Director

CFO to SPM

ADO (SPM)

25/09/25

F.T. letter is put up for signature, please.

C.F.O.
24/9/2025

Sumit Kumar
24/09/2025

my