



FIRE SAFETY CERTIFICATE

Certified that the Nigam Pratibha Vidyalaya (Co-ed) located at DDA, Flats Gazipur Dairy Farm, Delhi - 110096 comprised of Ground + 01 Upper floor (except Badminton Court), owned/occupied by Nigam Pratibha Vidyalaya (Co-ed), was granted FSC by this department vide letter No. F6/DFS/MS/School/NDZ/2022/98 dated 01/02/2022. The premises was re-inspected by the officer concerned of this department on 15/02/2025 in the presence of the Mrs. Veena Kumari (In - Charge) and found that school have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and the building premises is fit for occupancy of class Group B "Educational Building" Sub-Div. B-I for Gr. + 01 upper floor (except Badminton Court), with effect from 21/02/2025 for a period of **three years**, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 21/02/2025 at New Delhi by.


(ATUL GARG)
DIRECTOR
OK DELHI FIRE SERVICE

Copy to:-

1. The Director of Education, MCD, Udyog Sadan, Plot No. 419, FIE, Patparganj, Delhi - 110092.
2. The Principal, Nigam Pratibha Vidyalaya (Co-ed) located at DDA, Flats Gazipur Dairy Farm, Delhi - 110096.

Condition for the validity of fire safety certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building:- Nigam Pratibha Vidyalaya (Co-ed) located at DDA, Flats Gazipur Dairy Farm, Delhi-96
2. Type of occupancy:- Educational Group Gr.+01 Upper Floor (except Badminton Court)
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/School/NDZ/2022/98 dated 01/02/2022
5. Fire safety directives No.- F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011
6. Date of inspection:- 15/02/2025
7. Name of the inspecting officer:- Yashwant Singh Meena ADO (L.N)
8. Name & designation of officer From the building side:- Mrs. Veena Kumari (In - Charge)
9. Year of construction:- 2018
10. Applicant's letter No:- Diary no. 12207 dated 06/02/2025.

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Circular	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	06 mtr.	MR
	2) Gate width	NA	NA	NA
	3) Width of internal road	NA	NA	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	03 nos.	03 nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.5 mtr	1.5 mtr each	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	02 no.	02 no.	MR
	E. Width of corridor	1.5 mtr	1.5 mtr.	MR
	F. Door size	1.0 mtr.	1.0 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	08 Nos.	08 Nos.	MR
	2) Types	ABC & CO2	ABC, CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	N/A	N/A	N/A


2/16

	2) Length of hose reel hose	N/A	N/A	N/A
	3) Nozzle diameter	N/A	N/A	N/A
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	N/A	N/A	N/A
15.	Exit Signage.	N/A	N/A	N/A
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A

	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.


In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/School/NDZ/2022/98 dated 01/02/2022, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended.


17/2/2025
Signature of the Inspecting Officer
Name: - Yashwant Singh Meena
Designation: - ADO (L.N)

DO/East

Dy. C.F.O. (NDZ)

C.F.O.



19/2/2025
Director

ADP/LN

Sir.

F.T Letter is put up for sign. Please

Director


20/2/2025