



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No.F.6/DFS/MS/School/2025/NDZ/ 503

Dated: 09/06/2025

To,

The Manager,
Nigam Patibha Vidyalaya
Khurezi, Delhi-110051


Subject:-Regarding renewal of Fire Safety Certificate in r/o Nigam Patibha Vidyalaya located at Khurezi, Delhi-110051.

Sir,

This is in reference to your letter no. 078 dated 19/05/2025 on the subject cited above. In this connection, it is to inform you that the side was visited by officer concerned of this department on dated 27/05/2025 in presence of Mrs. Aastha Triwedi, In-Charge and observed that the management has still not complied the shortcoming by this department vide letter No. F.6/DFS/MS/School/2021/NDZ/660 dated 16/12/2021 (copy enclosed).

In view of the above, Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the shortcomings communicated vide above mentioned letter under intimation to this office for further action.

Yours faithfully

 6/6/2025

(VIRENDRA SINGH)
CHIEF FIRE OFFICER

Encl. As above

Copy to:-

The Director of Education (MCD)
15th Floor, E-Block, Dr. S.P. Mukahrjee Civic Center, JLN Marg, New Delhi-110002

eg~

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/School/2021/NDZ/ 660

Dated: 16/12/2021

To,

The Principal,
Nagar Nigam Prathmic Adrash Vidyalaya,
Khurezi I & II, Shahdara South,
Delhi-110051

Subject:- Regarding issuance of Fire Safety Certificate.

Sir,

With reference to your letter no. E.E. (Elect.)-II/Shah(S)/2021-2022/D-570 dated 27/10/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Ms. Puspa Devi, Incharge & Sh. Kuldeep Kumar Singh, J.E (Electric), Shahdara South Zone on dated 25/11/2021. The school building comprises of ground plus three upper floors. During the course of inspection following shortcoming was observed.

1. One additional staircase is not provided in the school building.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to rectify the above mentioned fire safety arrangements under intimation to this office for further necessary action.

Yours faithfully,


(Atul Gang)
Director

Copy to:-

The Director of Education, EDMC
Udyog Sadan, Plot No. 419, FIE,
Patparganj, Delhi -92