



C-20

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/2025/School/ 25

Dated: 15/01/2025

FIRE SAFETY CERTIFICATE

Certified that Nigam Pratibha Vidyalaya (School ID No-1253119) located at Rameshwar Nagar, Near Model Town, Delhi-110033 comprised of Ground & First floor only owned/ occupied by Nigam Pratibha Vidyalaya was granted FSC by this department vide letter No. F6/DFS/MS/School/2022/WZ/215 Dated 25.02.2022. The premises was inspected by the officer concerned of this department on 03.01.2025 in presence of Mr. Charles Hembrom (Principal) and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class Group B Educational with effect from15/01/2025 for a period of three years, subject to compliance of the conditions mentioned below:

Issued on15/01/2025 at New Delhi by

(Atul Garg)
Director

Ph:-011-23414000
OK

Copy to:-

1. The Dy. Director, Education Department, GNCT of Delhi, Civil Line Zone, 16 Rajpura Road, Delhi.
2. The Principal, Nigam Pratibha Vidyalaya at Rameshwar Nagar, Delhi-110033

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Nigam Pratibha Vidyalaya at Rameshwar Nagar, Near Model Town, Delhi-110033. (School ID No- 1253119)
2. Composition of Building : Ground & first floor only
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/School/2022/WZ/215 Dated 25.02.2022
6. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
7. Date of inspection : 03.01.2025
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Mr. Charles Hembrom (Principal)
10. Year of Construction : 1997
11. Applicant's letter No. : Letter No- Nil Dated:16.12.2024

	Minimum Standards on fire prevention and fire safety U/R 33	D.O.E Circular dated 01.03.2011 Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	06m	MR
	• Gate width	Directly Accessible	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5m	1.50m & 1.44m	MR
		NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	1.50m	2.5m	MR
	e. Width of Corridor	01m	01m	MR
	f. Door Size			
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers	05nos	05nos	MR
	• Types	ABC/Co2	ABC-05	MR
	• ISI marking	ISI Marked	Provided	MR

6	First-Aid Hose Reels.					
	<ul style="list-style-type: none">• Total numbers on each floor• Length of hose reel hose• Nozzle diameter	NA	NA	NA		
		NA	NA	NA		
		NA	NA	NA		
7	Automatic fire detection and alarming system.					
	<ul style="list-style-type: none">• Type of detectors• Location of Main Panel• Location of Repeater Panel• Alternate source of power• Hooters' Location	NA	NA	NA		
		NA	NA	NA		
		NA	NA	NA		
		NA	NA	NA		
		NA	NA	NA		
8	MOEFA	NA	NA	NA		
9	Public Address System.					
10	Automatic Sprinkler System.					
	<ul style="list-style-type: none">• Basement• Upper Floor• Sprinkler above false ceiling	NA	NA	NA		
		NA	NA	NA		
		NA	NA	NA		
11	Internal Hydrants					
	<ul style="list-style-type: none">• Size of riser/down-comer• Number of hydrants per floor• Hose Box	NA	NA	NA		
		NA	NA	NA		
		NA	NA	NA		
12	Yard Hydrants.					
	<ul style="list-style-type: none">• Total number of hydrants• Hose Box	NA	NA	NA		
		NA	NA	NA		
13	Pumping Arrangements.					
	<ul style="list-style-type: none">• Ground Level<ul style="list-style-type: none">➤ Discharge of main Pump➤ Head of Main pump➤ Number of main pumps➤ Jockey Pump out put➤ Jockey pump head➤ Standby Pump out put➤ Standby Pump Head➤ Auto Starting/ Manual stopping➤ Pump House Access• Terrace level<ul style="list-style-type: none">➤ Discharge of pump➤ Head of the pump➤ Power Supply➤ Auto Starting of pump	N/A	N/A	N/A		
		N/A	N/A	N/A		
		N/A	N/A	N/A		
		NA	NA	NA		
		NA	NA	NA		
		N/A	N/A	N/A		
		N/A	N/A	N/A		
		N/A	N/A	N/A		
		NA	NA	NA		
		NA	NA	NA		
		NA	NA	NA		
		NA	NA	NA		
		14	Captive Water Storage for fire fighting.			
		<ul style="list-style-type: none">• Underground tank capacity<ul style="list-style-type: none">➤ Draw-off connection➤ Fire service inlet➤ Access to tank• Overhead Tank capacity	NA	NA	NA	
			NA	NA	NA	
NA	NA		NA			
NA	NA		NA			
NA	NA		NA			

N/17

15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. F6/DFS/MS/School/2022/WZ/215 Dated 25.02.2022.

Signature of the Inspecting Officer

Name: - C.L. Meena

Designation: - ADO/RN

D.B. Mukharjee (DO/NW)

By cfo (wz)
08/01/2025

08/01/2025

CFO / 9/01/2025

Director 19/1/25

Any RN

conf - P.T.O.