



C-16



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/2025/School/173

Dated: 26 / 03 / 2025

To

The Principal,
Nigam Pratibha (Co-ed) School,
Rana Pratap Bagh, Delhi-110007

Sub: - Regarding grant of fire safety certificate in r/o Nigam Pratibha (Co-ed) School located at Rana Pratap Bagh, Delhi-110007.

Sir,

Please refer to your online e-mail dated: 07.03.2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was inspected by the officer concerned of this department on 19.03.2025 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of ground & first floor only. At the time of inspection Smt. Neeru Khatri (Principal) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

- 1 There is only one staircase provided width of 1.19m against the requirement of 1.50m or and additional staircase 75cm.
- 2 Electrical panel below in staircase needs to be removed/shifted in a safer place.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully

(Anil Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Dy. Director, Education Department, Keshavpuram Zone, MCD, Delhi.

21/3