

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001


No.F6/DFS/MS/2025/NDZ/ School/ 1150

Dated: 17/09/2025

FIRE SAFETY CERTIFICATE

Certified that the Nigam Pratibha Vidyalaya located at Prasad Nagar, New Delhi – 110005. comprises of Ground plus one upper floor only, was earlier granted FSC by this department vide letter No. F6/DFS/MS/School/SZ/2022/1066 dated 23/09/2022. Now, the premises was re-inspected by the officer concerned of this department on 08-09-2025 in the presence of Ms. Babita Rani and found that school have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and the first floor of building premises is fit for occupancy of class Group B “Educational Building” Sub-Div. B-I with effect from17/09/2025 for a period of three years subject to compliance of the conditions mentioned below:

Issued on17/09/2025 at New Delhi by.


(Virendra Singh)
Chief Fire Officer

Copy to:-

1. Director of Education, Govt. of NCT, Delhi.
2. The Incharge, Nigam Pratibha Vidyalaya located at Prasad Nagar, New Delhi – 110005.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area , occupancy and any deviation in construction etc. shall be verified from authority concerned This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
5. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
8. Any flammable material for interior decoration is prohibited.

INSPECTION REPORT

1. Name & address of the building:- Nigam Pratibha Vidyalaya located at Prasad Nagar, New Delhi – 110005.
2. Type of occupancy:- Educational Group B-I, Gr.+01 Upper Floor
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/School/SZ/2022/1066 dated 23/09/2022.
5. Fire safety directives No.- Director of education circular dated 01.03.2011
6. Date of inspection:- 08/09/25
7. Name of the inspecting officer:- Sh. Ravinder Singh (DO/CC)
8. Name & designation of officer
From the building side:- Ms. Babita Rani (Incharge)
9. Year of construction:-
10. Applicant's letter No:- letter no. nil dated 21/08/2025.

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirements as per previous inspection report	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	Provided	N/A
	2) Gate width	4.5 mts	Provided	N/A
	3) Width of internal road	NA	NA	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02	02	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.50 mt & if less than 0.75 mts	1.50 mts each	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01	01	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1.20 mtr.	Provided	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	12 a/c per hour	N/A	N/A
5.	Fire Extinguishers			

	1) Total numbers	06 Nos.	Provided	MR
	2) Types	ABC & CO2	Provided	MR
	3) ISI marking	ISI marked	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01	N/A	N/A
	2) Length of hose reel hose	30 m	N/A	N/A
	3) Nozzle diameter	5 mm	N/A	N/A
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	Provided	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A

	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	N/A	2500 ltr.	N/A
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:	Required	01 ABC type fire extinguisher is provided near elect. Panel	MR

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules if approved, we may renew the Fire Safety Certificate issued vide letter No. F6/DFS/MS/School/SZ/2022/1066 dated 23/09/2022, under Rule 35 of the Delhi Fire Service rules 2010, Accordingly, **FSC is recommended for approval & DFA** is put up for kind perusal and signature please.

Signature of the Inspecting Officer

Name :- Ravinder Singh
Designation :- D.O. ()

20/10/2025
CFO

12/9/2025

Principal Director

CFO to Secy.

12/09/25

CFO

1/10/25

1/10/25

1/10/25