



C/18

7



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/2025/School/ 25

Dated: 10/01/2025

To

The Principal
Nigam Utkrisht Vidyalaya,
Padam Nagar, Delhi-110007.

Sub:- Regarding issuance of fire safety certificate in r/o Nigam Utkrisht Vidyalaya (Jai Rani Bagh) located at Padam Nagar, Sarai Rolliha, Delhi-110007.

Sir,

Please refer to your letter no. nil dated 21.12.2024 on the subject cited above. In this connection this is to inform you the aforesaid building was inspected by the officers concerned of this department on 03.01.2025 in the presence of Mr. Jaikanwar (Care taker) to verify the status of the shortcomings already issued by this department vide letter No.F6/DFS/MS/School/2022/549 dated 08.09.2022 and status is as under: -

| S No. | Shortcomings | Status |
|-------|---|--------------|
| 1. | The main gate width of 3.60m provided against the requirements of 4.50m each. | Not Complied |
| 2. | Hose reel hose is provided but damaged/leakage condition. | Not Complied |
| 3. | Terrace level fire fighting pump capacity of 450lpm is provided but not functional. | Not Complied |
| 4. | Exit signage not provided at strategic locations in the school building. | Not Complied |
| 5. | Fire extinguisher is provided but not functional. | Not Complied |

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Dy. Director, Education Department, Civil Line Zone, 16 Rajpura Road, Delhi.