



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/EH/2025/SZ/183

Dated: 09/05/2025

FIRE SAFETY CERTIFICATE

Certified that M/s **Nik Bakers** (A unit of M.G. Bakers Pvt. Ltd) situated at N-3, Connaught Place, New Delhi-110001, building comprised of Ground + Mezzanine + 02 Upper floors but the restaurant running at ground floor & mezz. floor (storage), owned/occupied by M/s Nik Bakers (A unit of M.G. Bakers Pvt. Ltd, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/EH/NDZ/2022/SZ/92 dated 13/04/2022. The premise was re-inspected by the officer concerned of this department on 05/05/2025 in the presence of Sh. Gaurav (Manager) and found that the said premises is fit for occupancy class "**Assembly Group-D**" Restt. at **Ground floor & Mezz. floor (Storage)** with effect from 09/05/2025 for a period upto **31/03/2028** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 09/05/2025 at New Delhi by

(ATUL GARG)
DIRECTOR

Ph. 011-23414000

Copy to: -

1. The Joint Commissioner of Police (Lic.), First Floor, Police Station Defence Colony, New Delhi-110049 (w.r.t. online Id. No. **2025042507190** dated 25/04/2025)
2. Authorized Signatory, M/s Nik Bakers (A unit of M.G. Bakers Pvt. Ltd) situated at N-3, Connaught Place, New Delhi-110001

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1.	Name & address of the building	M/s Nik Bakers (A unit of M.G. Bakers Pvt. Ltd) situated at N-3, Connaught Place, New Delhi-110001		
2.	Type of Occupancy	Assembly, Group D (Eating House)		
3.	Building Comprised of	Ground + Mezz. + 02 Upper floors (Rest. running at Gr. Floor + Mezz. Floor-Storage)		
4.	Type of Case	Renewal		
5.	Details of previous NOC No.	F6/DFS/MS/EH/NDZ/2022/92 dated 13/04/2022		
6.	Fire Safety directives Letter No.	Nil		
7.	Date of inspection	05/05/2025		
8.	Name of the Inspecting Officer	ADO (SJ)		
9.	Name and designation of Officer from the building side	Sh. Gaurav (Manager)		
10.	Year of Construction	Old Heritage building		
11.	Applicant's letter No./Online Appl	No. 2025042507190 dated 25/04/2025		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Requirement Rule 35(6)	Provided at site	Remarks MR/NMR
1.	Access of building			MR
	• Road width	9 mtr	13 mtr	N/A
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			MR
	• Upper floors (Mezz. Floor)	01	01	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases			MR
	• Upper floors	0.50 mtr	0.50 mtr	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits			N/A
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	2 mtr	2 mtr	MR
3.	Compartmentation			N/A
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Managements System			N/A
	• Basements	N/A	N/A	N/A
	• Upper floors	12 ACPH	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	04 Nos	08 Nos	MR
	• Types	ABC & CO ₂	ABC & CO ₂	MR
	• ISI marking	Required	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	One	One	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR

7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detector Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Required	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor (Mezz. Floor) Sprinkler above false ceiling 	N/A	N/A	N/A
		Required	Provided	MR
		N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	100 mm	100 mm	MR
		One	One	MR
		One	One	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	450 LPM	450 LPM	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity Draw of connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		20,000 ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of lift lobby Communication in lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	N/A	N/A	N/A
		N/A	N/A	N/A


N-14

19.	Fire Control Room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection. The shortcomings communicated by this department vide letter No. F.6/DFS/MS/EH/2025/149 dated 07/04/2025 found rectified.

Keeping in view of the ~~deemed~~ compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/EH/NDZ/2022/SZ/92 dated 13/04/2022, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA letter is put up for approval and signature please.


 Signature of the Inspecting Officer
 Name: Santosh Kumar
 Designation: ADO (SJ)

DO (CD)

Rel
6/5/25

Dy. C.O. (ms)

L.V.P
09/05/25

C.F.O.
9/5/2025

Director

U. K. Singh

U. K. Singh
09/5/25
①