

c 56

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE

No. F.6/DFS/MS/School/2025/SZ/ 98

Dated: 31/01/2025

FIRE SAFETY CERTIFICATE

Certified that the **Mira Model School**, B-Block, Janakpuri, New Delhi-110058, comprised of four blocks namely A, B, C & D. Block-A is having ground plus one upper floor, Block-B is having Ground plus one upper floor & small basement (not in use and lying vacant), Block-C is having ground plus three upper floors and Block-D is having Basement (storage), Ground plus three upper floors, owned/occupied by Mira Model School was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2021/SZ/1050 dated 21.12.2021. The School building was re-inspected by the officer concerned of this department on 20.01.2025 in the presence of Cap. Jaswant, and found that the building/ premises is fit for occupancy class B 'Educational Building' with effect from 31/01/2025 for a period of three years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 31/01/2025 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. The Principal, Mira Model School located at B-Block, Janakpuri, New Delhi-110058.
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat, New Delhi.
3. The Executive Engineer (Bldg.), MCD, Civic Centre, Minto Road, New Delhi.

for information regarding use of basement.

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws and use of the basement will only be allowed after permission from MCD. Presently basement used as storage & vacant.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/23

INSPECTION REPORT

1. Name & address of the building : Mira Model School, B-Block, Janakpuri, New Delhi-110058
2. Type of Occupancy : Educational
3. Building Composition : Comprised of four blocks namely A, B, C & D (Interconnected). Block-A is having G+1 floor, Block-B is having G+1 & basement (Less than 200 sq. Mtrs., is not in use and lying vacant), Block-C is having G+3 floors and Block-D is having Basement (storage) G+3 floors.
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2021/SZ/1050 dated 21.12.2021
6. Fire Safety directives letter No : N/A
7. Date of inspection : 20.01.2025
8. Name of Inspecting Officer : A.D.O. R.K. Yadav
9. Name and designation of officers
From the building side : Cap. Jaswant
10. Year of Construction : 1978
11. Applicant's letter No. : Online email Id abcfiresystems@hotmail.com dated 16.12.2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible 4.5 m N/A	Provided 3.85 & 3.1 m N/A	M/R M/R, old case N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	03 No.'s 02 No.'s	3 nos. Provided Blk-B-01 & Blk-D-02	M/R M/R
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	1.50 m 1.50 m	1.67, 1.66 & 1.53 m .88-1.12 m in Blk-B & 1.66 & 1.17 m in Blk-D	M/R M/R, old case
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A Required	N/A N/A Provided	N/A N/A M/R
	d. No. of continuous staircases to terrace	1.50 m	1.78 m	M/R
	e. Width of Corridor	1.0 m	.98 to 1.15 m	M/R, old case
	f. Class Room Door Size			
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	Required Required	Exhaust fans are provided Natural ventilation provided	M/R M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	30 no's ABC/CO ₂ type ISI marked	Provided Provided Provided	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each block Length of hose reel hose Nozzle diameter 	01 no. 30 mtrs 5 mm	Provided Provided Provided	MR MR MR

7. Automatic fire detection and alarming system				
<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A	N/A	N/A	
	N/A	N/A	N/A	
	N/A	N/A	N/A	
	N/A	N/A	N/A	
	N/A	N/A	N/A	
	N/A	N/A	N/A	
8. MOEFA	N/A	N/A		N/A
9. Public Address System	N/A	Provided		N/A
10. Automatic Sprinkler System				
<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	Required	Provided		MR
	N/A	N/A		N/A
	N/A	N/A		N/A
11. Internal Hydrants				
<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A	100 mm		N/A
	N/A	One		N/A
	N/A	One		N/A
12. Yard Hydrants				
<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A		N/A
	N/A	N/A		N/A
13. Pumping Arrangements				
<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual Stopping 	N/A	N/A		N/A
	N/A	N/A		N/A
	N/A	N/A		N/A
	N/A	N/A		N/A
	N/A	N/A		N/A
	N/A	N/A		N/A
	N/A	N/A		N/A
	N/A	N/A		N/A
	N/A	N/A		N/A
	N/A	N/A		N/A
<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	900 LPM	Provided		MR
	30 m	Provided		MR
	Required	Provided		MR
	Required	Provided		MR
14. Captive Water Storage for fire fighting				
<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity 	N/A	N/A		N/A
	N/A	N/A		N/A
	N/A	N/A		N/A
	N/A	N/A		N/A
	2500 ltrs	Provided		MR
15. Exit Signage.	Required	Provided		MR
16. Provision of Lifts. No Lift				
<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A		N/A
	N/A	N/A		N/A
	N/A	N/A		N/A
	N/A	N/A		N/A
	N/A	N/A		N/A

N/25

	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Note: - School building comprised of four blocks namely A, B, C & D (Interconnected). Block-A is having ground plus one upper floor, Block-B is having Ground plus one upper floor & basement (Less than 200 sq. Mtrs., is not in use and lying vacant), Block-C is having ground plus three upper floors and Block-D is having Basement (storage as per undertaking given by school management), Ground plus three upper floors.

In view of the compliance/deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F.6/DFS/MS/School/2021/SZ/1050 dated 21.12.2021, renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

R. K. Yadav
21/01/2025
Signature of Inspecting Officer
Name: - R.K. Yadav
Designation: - ADO (JKP)

~~D.O. (8W)~~

R. K. Yadav
28/1/25

CFO
28/01/2025

Director
28/1/25

ADO/JKP