

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

No.F6/DFS/MS/School/NDZ/2025/ 1157

Dated: 18 / 09 / 2025

**FIRE SAFETY CERTIFICATE**

Certified that the Nisheman Primary School located at 21, Raj Niwas Marg, New Delhi- 110054, comprised of Ground + 01 upper floor was granted FSC by this department vide letter No.F6/DFS/MS/School/NDZ/2022/727 dated 29.06.2022. The premises was re-inspected by the officer concerned of this department on 04.09.2025 in the presence of Principal and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 01.03.2011 that the building is fit for occupancy class (Group-B) "Educational Building" with effect from .....18/09/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to conditions under rule 38 of Delhi Fire service Rules, 2010 printed below.

Issued on .....18/09/2025.....at New Delhi by

  
17/09/2025  
(Virendra Singh)  
Chief Fire Officer  
Delhi Fire Service  
o/c 18/09

**Copy to:-**

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Principal, Nisheman Primary School at 21, Raj Niwas Marg, New Delhi -110054.

**Conditions for the validity of Fire Safety Certificate**

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

# INSPECTION REPORT

1	Name and address of the building:	Nisheman Primary School at 21, Raj Niwas Marg, New Delhi -110054.
2	Type of occupancy with details of floors:	"Educational Building" (Group -B) Ground + 01 upper floor
3	Type of case:	Renewal case
4	Details of previous FSC:	F6/DFS/MS/School/NDZ/2022/727 dated 29.06.2022
5	Fire safety directives no.:	NA
6	Date of inspection:	04.09.2025
7	Name of the inspecting officer:	ADO (SPM)
8	Name and designation of the officer from the building side:	Principal
9	Year of construction:	Old
10	Reference letter no.:	Letter outdoor diary No. 4111 dated 25.07.2025

S. No	Minimum Standards on fire Prevention and fire safety requirements U/R 33		As per Education Circular	Provide at site	Remarks MR/NM R
1	Access to Building				
	A	Road width	06 m	06 m	MR
	B	Gate width	Required	4.5 m	MR
	C	Width of internal roads	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits				
	A	No. of Staircase:			
		a) Upper floor	02 nos.	02 nos.	MR
		b) Basements	NA	NA	NA
	B	Width of the Staircase:			
		a) Upper floor	1.50 m	2.18 m & 2.40 m	MR
		b) Basements	NA	NA	NA
	C	Protection of Exits			
		a) Fire check door	NA	NA	NA
		b) Pressurization	NA	NA	NA
	D	No. of continuous staircase to terrace:	01 no.	01 no.	MR
	F	Width of the corridor	1.5 m	1.5 m	MR
E	Door size	1.0 m	1.0 m	MR	
3	Compartmentation:				
	A	Fire check doors	NA	NA	NA
	B	Sealing of electrical shafts	NA	NA	NA
	C	Fire rating of shaft doors	NA	NA	NA
	D	Water curtain	NA	NA	NA
	E	Fire dampers	NA	NA	NA
4	Smoke management System:				
	A	Basements	NA	NA	NA
	B	Upper floors	12 ACPH	Natural/ Ventilated	MR
5	Fire extinguishers				
	A	Total numbers	08 nos.	08 nos.	MR
	B	Types	Co2 & ABC	Provided	MR
	C	ISI marking	Required	Provided	MR




6	<b>First Aid Hose reel</b>			
	A	Total no. at each floor	NA	NA
	B	Length of Hose Reel	NA	NA
	C	Nozzle diameter	NA	NA
7	<b>Automatic Fire Detection and Alarm System (ADAS)</b>			
	A	Type of Detectors	NA	NA
	B	Location of main Panel	NA	NA
	C	Location of Repeater Panel	NA	NA
	D	Alternate power Source	NA	NA
	E	Hooter's location	NA	NA
8	<b>MOEFA</b>			
9	<b>Public Address System</b>			
10	<b>Automatic Sprinkler System</b>			
	A	Basement	NA	NA
	B	Upper Floor	NA	NA
	C	Sprinklers above false ceiling	NA	NA
11	<b>Internal hydrants</b>			
	A	Size of the riser/down comer	NA	NA
	B	No. Of hydrants per floor	NA	NA
	C	Hose box	NA	NA
12	<b>Yard Hydrants</b>			
	A	Total no. of hydrants	NA	NA
	B	Hose box	NA	NA
13	<b>Pumping arrangements</b>			
	A	Ground Level		
		a) Discharge of main pump	NA	NA
		b) Head of main pump	NA	NA
		c) Number of main pump	NA	NA
		d) Discharge of jockey pump	NA	NA
		e) Head of jockey pump	NA	NA
		f) Discharge of Standby pump	NA	NA
		g) Head of Standby pump	NA	NA
		h) Auto starting/ manual stopping	NA	NA
	B	Terrace Level		
		a) Discharge of terrace pump	NA	NA
		b) Head of terrace pump	NA	NA
		c) Alternate power supply	NA	NA
		d) Auto starting of pump	NA	NA
14	<b>Captive Water Storage for Fire Fighting</b>			
	A	Underground tank capacity	NA	NA
	B	Draw off connection	NA	NA
	C	Fire Service Inlet	NA	NA
	E	Access to tank	NA	NA
	D	Overhead tank capacity	NA	NA
15	<b>Exit Signage</b>			
16	<b>Provision of lift</b>			
	A	Pressurization of lift shaft	NA	NA
	B	Pressurization of lift lobby	NA	NA
	C	Communication in lift car	NA	NA
	D	Fireman switch	NA	NA
	E	Lift signage	NA	NA
17	<b>Standby Power Supply</b>			
			NA	NA

80 14

18	<b>Refuge Area</b>			
A	location	NA	NA	NA
B	Total area	NA	NA	NA
19	<b>Fire Control Room</b>			
A	Fire Detection System panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	P A system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plan	NA	NA	NA
20	<b>Special Fire Protection for special risk if any:</b>			NA


The fire protection system provided in the school were tested, checked and random and found functional at the time of inspection.

Keeping in view of deemed compliance of the minimum standards on fire prevention and fire safety required under the rules of the FSC issued vide letter No. F6/DFS/MS/School/NDZ/2022/727 dated 29.06.2022 **renewal** under rule 35 of the Delhi Fire Service rules 2010, is recommended.

  
 Signature of the Inspecting Officer  
 Name Sumit Kumar  
 Designation ADO (SPM)

DO (CD)

  
8/9/25

  
By C.F.O. (MS)

  
10/9/25

  
C.F.O.

  
11/9/2025

Principal Director

C.F.O. to Sum.

  
12/09/25

C.F.O.

  
15/9/2025


  
16/9

DP (CO)

ADO (SPM)

F.T. letter is put up for signature, please.

  
C.F.O.

  
15/9/2025

  
16/09/2025

MS