

८/१७



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/School/NDZ/2025/ 121

Dated: 21/02/2025

To,

The Principal,
Nizamia Public School
E – II, Gali No. 18, Nehru Vihar
Mustafabad, Delhi – 110094.

Subject: - Regarding grant of Fire Safety Certificate in r/o Nizamia Public School located at E – II, Gali No. 18, Nehru Vihar Mustafabad, Delhi – 110094.

Sir,

This has a reference to your Email dated 07/02/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 15/02/2025 in the presence of Manager and observed that building comprised of ground plus three upper floors.

Following shortcomings were observed during time of inspection:

1. First-Aid-Hose Reel at provided but not functional.
2. Fire pump of 450 LPM provided but not functional.
3. Over head water storage tank of capacity 10,000 liters found removed.
4. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Joint Director of Education, MCD, Udyog Sadan, Plot No.419, FIE, Patargang, Delhi - 110092.