



75
आजादी का
अमृत महोत्सव
207

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No. F6/DFS/MS/EH/SZ/2026/380

Dated: 28/04/2026

To,

The Commissioner MCD,
Civic Centre, Minto Road,
New Delhi- 110002.

Sub: Regarding renewal of FSC from fire safety point of view in r/o. M/s. Nukkad Café and Bar, at SH-07, Third Floor, Kailash Colony, New Delhi-110048.

Sir,


Please refer to your online application no. No. 2026031002632 dated 10/03/2026, on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 27/03/2026 in the presence of Sh. Rajender Sharma to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the said eating house is running at third floor in a building comprised of basement + ground + 03 upper floors, was issued FSC vide letter no. F6/DFS/MS/EH/2023/SZ/354 dated 05/12/2023. Fire safety arrangements such as Fire Extinguishers, MOEFA etc provided. However the following shortcomings were observed.

1. First Aid Hose reel is provided but it is not functional.
2. MOEFA is provided but not functional.
3. Internal Hydrant is provided but not functional.
4. Main fire pump capacity of 2280 LPM, Standby pump capacity of 2280 LPM (Provided at terrace), Jockey pump capacity of 180 LPM, are provided but not on auto-mode.
5. 30K underground tank is provided against requirement of 1,00,000ltrs. & 10,000ltrs. Overhead tank also found removed.
6. Exit Signage's are found removed.

In view of above Shortcomings, the application for renewal of Fire safety Certificate is cannot considered at this stage & rejected. The occupancy of the Building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier.

Yours faithfully,


A.K. Malik
Dy. Chief Fire Officer
South Zone

Copy To: -

1. The Owner/occupier M/s. Nukkad Café and Bar, at SH-07, Third Floor, Kailash Colony, New Delhi-110048. Online application No. 2026031002632 dated 10/03/2026.