



No. F6/DFS/MS/School/SZ/2025/1283

Dated: 31/10/2025

FIRE SAFETY CERTIFICATE

Certified that the Nursery Block, Delhi Public School located at Mathura Road, New Delhi, building comprised of Basement plus Ground plus one upper floor, owned / occupied by Delhi Public School was issued FSC vide letter No. F6/DFS/MS/School/SZ/2022/1024 dated 16/09/2022. The school building was re-inspected by the officer concerned of this department on 08/10/2025 in presence of Dr. Ram Singh and found that all the Fire Prevention and Fire Safety arrangement provided found in good working condition. The premises have therefore deemed rule 33 of Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class "Educational Building" (Group-B) with effect from 31/10/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 31/10/2025 at New Delhi by.


(A.K. Malik)
Dy. Chief Fire Officer
o/c Delhi Fire Service

Copy to: -

1. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi - 110054.
2. The Principal, Nursery Block, Delhi Public School located at Mathura Road, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. Basement shall be used as per NBC/UBBL.
7. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	Nursery Block, Delhi Public School located at Mathura Road, New Delhi.		
2	Building is comprised of	Basement plus Ground plus one upper floor		
3	Type of occupancy	Educational Building Group -B		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/SZ/2022/1024 dated 16/09/2022		
6	Fire safety directives letter no.	Nil		
7	Date of inspection	08/10/2025		
8	Name of the inspecting officers	Yashwant Singh Meena, ADO/Mathura Road		
9	Name of the designation of officer from the building side	Dr. Ram Singh		
10	Year of construction	1995-96		
11	Applicant's letter no.	Outdoor Diary No. 5606 dated 03/09/2025		
S.No	Minimum standard of fire prevention and fire safety U/R 33	NBC Part - IV Requirement	Provided at site	Remarks MR/NMR
1	Access to Building:			
	A Road width	6.0 mtrs.	6.0 mtrs.	MR
	B Gate width	4.5 mtrs.	Provided	MR
	C Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Upper floor	01 no.	01 no.	MR
	b Basement	01 no. & 01 no. ramp	01 no. & 01 no. ramp	MR
	B Width of staircases			
	a Upper floor	1.50 mtr.	1.58 mtr.	MR
	b Basement	1.50 mtr.	1.50 mtr. & Ramp-1.45 mtr.	MR
	C Protection of exits			
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	N/A
	D No. of continuous staircases to terrace	01 no	01 no	MR
	E Width of corridor	1.50 mtrs.	Provided	MR
	F Door size	1.0 mtr. (for class room)	1.0 mtr. (for class room)	MR
3	Compartmentation:			
	A Fire check door	Required	Provided	MR
	B Sealing of electrical shafts	N/A	N/A	N/A
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
4	Smoke Management System:			
	A Basement	N/A	N/A	N/A
	B Upper floor	N/A	N/A	N/A

L @


5. Fire Extinguisher:				
A	Total numbers	05 nos.	05 nos.	MR
B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
C	ISI marking	ISI Marked	ISI Marked	MR
6 First-Aid-Hose Reel:				
A	Total numbers of each floor	01 no	01 no	MR
B	Length of hose reel hose	30 m	30 m	MR
C	Nozzle diameter	05 mm	05 mm	MR
7 Automatic Fire Detection and Alarming System:				
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooters	N/A	N/A	N/A
8	MOEFA:	N/A	N/A	N/A
9	Public Address System:	N/A	Provided	N/A
10 Automatic Sprinkler System:				
A	Basement	Required	Provided	MR
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
11 Internal Hydrants:				
A	Size of riser/down-comer	N/A	N/A	N/A
B	Number of hydrants per floor	N/A	N/A	N/A
C	Hose box	N/A	N/A	N/A
12 Yard Hydrants:				
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
13 Pumping Arrangements:				
1 Ground level				
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
2 Terrace Level				
A	Discharge of pump	480 + 180 LPM	480 + 180 LPM	MR
B	Head of the pump	40 m each	50 & 40 m	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR
14 Captive Water Storage for Fire Fighting:				
A	Underground tank capacity	50,000 ltr.	Provided	MR
B	Draw-off connection	Required	Provided	MR
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	12,500 liters	20,000 liters	MR

24/25

15	Exit Signage:	Required	Provided	MR
16	Provision of Lifts:			
	A Pressurization of lift shaft	N/A	N/A	N/A
	B Pressurization of lift lobby	N/A	N/A	N/A
	C Communication in lift car	N/A	N/A	N/A
	D Firemen's grounding switch	N/A	N/A	N/A
	E Lift signage	N/A	N/A	N/A
17	Standby Power Supply:	N/A	N/A	N/A
18	Refuge Area:			
	A Total area	N/A	N/A	N/A
	B Location	N/A	N/A	N/A
19	Fire Control Room:			
	A Detector system panel	N/A	N/A	N/A
	B Flow switch panel	N/A	N/A	N/A
	C PA system panel	N/A	N/A	N/A
	D Battery backup	N/A	N/A	N/A
	E Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A


The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter F6/DFS/MS/School/SZ/2022/1024 dated 16/09/2022, renewal under Rule 35(6) of the Delhi Fire Service rules 2010, is recommended.


 Signature of the Inspecting Officer
 Name Yashwant Singh Meena
 Designation ADO/Mathura Road

D.O/SD


10/10/25


Dy. Cfo (S2)


A.K. MALIK


Principal Director

Dy. Cfo to Issue.


Dy. Cfo (S2)


17/10/25


D.O/SD


24/10/25
A.K. MALIK