

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE
CONNAUGHT PLACE: NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/ 809

Dated: 20/06/2025

FIRE SAFETY CERTIFICATE

Certified that the building of **Nursery School** located at SPG Training Complex, Plot No. 21, Sector-21, Dwarka, New Delhi-110077 comprised of **Ground + 01 upper floors**, was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/SZ/School/2022/734 dated 04/07/2022. The premise was re-inspected by the officer concerned of this department on 05/06/2025 in the presence of Sh. Vijay Kr. Sharma and found that said premises have complied with the fire prevention and fire safety requirements in accordance with Director of Education Circular No. 3298-3398 dated 01/03/2011 and that the school building/premises is fit for occupancy class "**Educational Group B**" (School) with effect from 20/06/2025 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 20/06/2025 at New Delhi by

(ATUL GARG)
DIRECTOR

Ph. 011-23414000

Copy to: -

1. Principal, Nursery School at SPG Training Complex, Plot No. 21, Sector-21, Dwarka, New Delhi-110077
2. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
5. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, prior to its expiry.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

N-9

INSPECTION REPORT				
1.	Name & address of the building	Nursery School located at SPG Training Complex, Plot No. 21, Sector-21, Dwarka, New Delhi-110077		
2.	Type of Occupancy	Educational		
3.	Building Comprised of	Ground + 01 upper floors.		
4.	Type of Case	Renewal		
5.	Details of previous NOC No.	F6/DFS/MS/SZ/School/2022/734 Dt. 04/07/2022		
6.	Fire Safety directives Letter No.	DOE Circular No. 3298 to 3398 dated 01/03/2011		
7.	Date of inspection	03/06/2025		
8.	Name of the Inspecting Officer	ADO (SJ)		
9.	Name and designation of Officer from the building side	Sh. Vijay Kr. Sharma		
10.	Year of Construction	2019		
11.	Applicant's letter No.	Form 'J' received through outdoor diary No. 2097 dated 26/05/2025		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	Provided	MR
	• Gate width	4.5 mtr	Abut on road	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 Nos	02 Nos	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.5 mtr each	Provided	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	Provided	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	02 Nos	02 Nos	MR
	e. Width of Corridor	1.50 mtr	Provided	MR
	f. Door Size	1.20 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	2nos/Floor	Provided	MR
	• Types	ABC or CO ₂	ABC & CO ₂	MR
	• ISI marking	ISI Marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	N/A	Provided	N/A
	• Length of hose reel hose	N/A	30m	N/A
	• Nozzle diameter	N/A	5mm	N/A

SR

N-10

7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	Smoke	N/A
	• Location of Main Panel	N/A	Ground floor	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	Battery backup	N/A
	• Hooters' Location	N/A	Near stairs	N/A
8.	MOEFA	N/A	Provided	N/A
9.	Public Address System	N/A	Provided	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down- comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	02 Nos	N/A
	• Hose Box	N/A	Provided	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	N/A	2280 LPM	N/A
	➤ Head of main pump	N/A	70m	N/A
	➤ Number of main pumps	N/A	One	N/A
	➤ Jockey pump out put	N/A	180 LPM	N/A
	➤ Jockey pump head	N/A	70m	N/A
	➤ Standby Pump out put	N/A	2280 LPM	N/A
	➤ Standby Pump Head	N/A	70m	N/A
	➤ Auto Staring/Manual stopping	N/A	Provided	N/A
	➤ Pump House Access	N/A	Provided	N/A
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	3,00,000 ltr	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby Power Supply	N/A	DG Set	N/A
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA


N-11

19.	Fire Control Room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	CO ₂ fire extinguisher provided near electric panels		MR

The fire protection systems provided in the building were checked, tested at random and found functional at the time of inspection


Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the DOE circular, the fire safety certificate issued vide letter No. F6/DFS/MS/School/2022/734 dated 04/07/2022, renewal under rule 37 of Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.



Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (DWK)

~~DO (SW)~~


11/6/25


12/6/25

~~Director~~



12/6/25


12/6/25


12/6/25

Sir, F.T letter is put up for your sig. pl


12/6/25


16/6/25