

CP29

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No. F6/DFS/MS/NDZ/2025/ 411

Dated: 22/08/2025

To,
The Assistant Engineer (E) -II,
R.M.L. Elect. Division, C.P.W.D,
Dr. RML, Hospital, New Delhi.


Sub:- Regarding issuance of Fire NOC of Nursing College Block Building at Dr. RML Hospital, New Delhi.

Sir,
This has reference to your A/E (E)/Dr. RML ED/2025-26/123 dated 08.07.2025, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 04/08/25 in the presence of Mr. Manish and following shortcomings were observed:

1. Alternate exit near to college block blocked by dumping of wastage and also locked, Hence only one staircase is available for the college block occupants.
2. Hose Reel & pump found nonfunctional. Nozzle also found removed from some hose reel.
3. Over head tank of 5000 liter found removed.

In view of above, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Director/Superintendent, Dr. RML, Hospital, New Delhi.
2. The Executive Engineer (Electrical), CPWD, Dr. RML Hospital, New Delhi.