

C/61

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No. F6/DFS/MS/School/2025/ 590

Dated: 14 / 07 / 2025

To

Mr. R.S.Godbole
Chairman, DMECS/NMSSS,
Nutan Marathi Senior Sec School,
Walchand Place, Aram Bagh, Paharganj, New Delhi.

Sub: Regarding issuance of FSC in r/o Nutan Marathi Senior Sec School, Walchand Place, Aram Bagh, Paharganj, New Delhi.

Sir,

This has reference to your letter no. NMS/282 dated 03/06/25, on the subject cited above. In this regard, it is to inform you that the site was visited by officer concerned of this department on 07/07/25 in the presence of Principal and following shortcomings are observed.

1. Hose reel & pump of 450 LPM is not provided.
2. Over head tank of 10,000 liter is not provided

In view of above, fire safety certificate (FSC) cannot be issued at this stage. Therefore, you are requested to rectify the above shortcomings at the earliest for further consideration in the matter.

Yours faithfully,

(Atul Gang)
DIRECTOR
Delhi Fire Service

Copy to:-

The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.