

C-87

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/2025 1154

Dated:-08/04/2025

To,

The Addl. Commissioner of Police (Lic),
1st floor, Defence Colony Police Station,
New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/s O2 Multicuisine Restaurant, 23 A 1st floor, NN tower B Block, Road No. 44, Pitampura, Delhi.

Sir,

This has reference to on line ID No. 2025031203381 dated 12.03.25, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 28/03/25 in the presence of Mr. Rana Manager and following shortcomings were observed:

1. Hose reel nozzle found missing.
2. Hydrant found nonfunctional and hoses & branch found missing.
3. Terrace pump of 180 LPM found removed.
4. Pump not in auto provision.

In view of above, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify/ clarify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:

1. The Manager, O2 Multi Cuisine Restaurant, 23 A 1st floor, NN tower B Block, Road No. 44, Pitampura, Delhi.