

C-89

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZ/2025/166

Dated: 26/03/2025

**FIRE SAFETY CERTIFICATE**

Certified that the Om International Guest House located at 7/7, D.B.G. Road, Pahar Ganj, New Delhi comprised of Ground + 03 Upper floors, Ground floor (reception + office), 1<sup>st</sup> floor to 3<sup>rd</sup> floor (12 guest rooms at each floor), total 36 guest rooms owned/occupied by Om International Guest House was earlier granted FSC by this department vide letter No. F6/DFS/MS/GH/NDZ/2022/109 dated 18.02.2022. Now, the premises was inspected by the officer concerned of this department on 12.03.2025 in the presence of Sh. Mahavir Sharma (Manager) and found that the said guest house building comprised of ground and three upper floor, has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Residential, Sub Division-A-1 Ground floor (reception + office), 1<sup>st</sup> floor to 3<sup>rd</sup> floor (12 guest rooms at each floor), total - 36 guest rooms only with effect from ~~26/03/25~~ for period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued .....26/03/2025.....at New Delhi by.

(Atul Garg)  
Director

Ph: 011-23414000

Copy to:-

1. The Commissioner, Municipal Corporation of Delhi, to ensure the occupancy detailed above.
2. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defense Colony New Delhi. ID no. 2025030402787 dated 05.03.2025.
3. The Manager, Om International Guest House located at 7/7, D.B.G. Road, Pahar Ganj, New Delhi.

**Condition for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the MHA portal along with a copy of this Certificate, **six months** prior to its expiry".



**INSPECTION REPORT**

1. Name & address of the building:- Om International Guest House located at 7/7, D.B.G. Road, Pahar Ganj, New Delhi
2. Type of occupancy:- Residential, Sub Division-A-1  
Gr. + 03 Upper floors (total 36 Guest rooms)  
Ground floor (reception and hall), 1<sup>st</sup> floor to 3<sup>rd</sup> floor  
(12 guest rooms at each floor)
3. Type of case:- Renewal
4. Details of previous FSC:- No. F6/DFS/MS/GH/NDZ/2022/109 dated 18.02.2022.
5. Fire safety directives No.- N/A
6. Date of inspection:- 12.03.2025
7. Name of the inspecting officer:- ADO (RN)
8. Name & designation of officer  
From the building side:- Sh. Mahavir Sharma (Manager)
9. Year of construction:- 1995 as per MHA portal detail
10. Applicant's letter No:- ID NO. 2025030402787 dated 05.03.2025

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing fire safety arrangements	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	N/A	06 mtr. ✓	N/A
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	A. Number of staircases			
	1. Upper floors	01 Nos.	01 Nos. ✓	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	0.80 mtr.	1.25 mtr. ✓	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01	01	MR
	E. Width of corridor	1.5 mtr.	1.5 mtr.	MR
	F. Door size	1 mtr.	1 mtr.	MR
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management System</b>			
	1) Basements	NA	N/A	N/A
	2) Upper floors	Required	Provided	MR
<b>5.</b>	<b>Fire Extinguishers</b>			
	1) Total numbers	08 Nos.	08 Nos. ✓	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
<b>6.</b>	<b>First-Aid Hose Reel</b>			
	1) Total number of each floor	01	01	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors CO	Required	Provided	MR
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A


N/32				
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	100 mm ✓	MR
	2) Number of hydrants per floor	01	01 ✓	MR
	3) Hose box	01	01	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM ✓	MR
	b) Head of pump	40 mtr.	40 mtr. ✓	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	3000 ltr.	3000 ltr. ✓	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A



20.	Special Fire Protection System for Protection of special Risk, if any:	NA
-----	--	----


The fire protection systems provided in the guest house building were randomly tested, checked and found functional at the time of inspection.


In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/GH/NDZ/2022/109 dated 18.02.2022, renewal under rule 37 of the Delhi Fire Service rules 2010, is recommended up to third floor.

  
Signature of the Inspecting Officer  
Name: - C.L. Meena  
Designation: - ADO (RN)


DO/CD

  
17/3/25

  
Dy. CFS (RN) 22

  
18/03/25


C.F.O.


  
20/3/2025  
Director



As approved, P.T. letter is setup for your signature please.

  
Director (DFS)

  
25/03/2025  
ADO (RN)

  
V. Bhandari  
27/03/25

