



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2025/ 620

Dated: 07/08/2025

C/56
7.5
आजादी का
अमृत महोत्सव

To,

The Principal/Incharge,
Om Public School,
832, Rishi Nagar, Near Krishna Mandir,
Rani Bagh Delhi-110034.

Sub: Inspection report in r/o. Om Public School, located at 832, Rishi Nagar, Near Krishna Mandir, Rani Bagh Delhi-110034.

Sir,


With reference to your Letter no. 2025/011 dated 02/07/2025, on the subject cited above. In this connection, it is to inform you that the said premises was inspected by the officer concerned of this department on 17/07/2025, in the presence of Mrs. Krishan Gopal Suri to see the functioning of the fire safety arrangements/equipment's provided in the building.

During inspection, it has been observed that the said school building is comprised of ground + 03 upper floors, was already issued FSC vide letter No. F6/DFS/MS/School/WZ/2022/706 dated 24/06/2022. Fire Safety Arrangements such as, Fire Extinguishers, First Aid Hose Reels, Terrace pump etc, are provided. However, following shortcomings were observed: -

1. First Aid Hose Reel is provided but not functional.
2. Terrace fire pump of 450 LPM & 180 LPM provided but not functional.
3. Overhead water tank capacity of 1,000 ltrs provided against the requirement of 5,000 ltrs.
4. Exit signage's are found removed.

In view of above shortcomings, the application for renewal Fire Safety Certificate is **rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,


21/8/2025
Virendra Singh
(Chief Fire Officer)

Copy To:-

1. The Director, Directorate of Education Old Secretariat Delhi - 110054.

12
31/7/2025