




GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001




No. F6/DFS/MS/2025/WZ/School/ 1280

Dated: 31/10/2025

**FIRE SAFETY CERTIFICATE**

Certified that the Om Public School, located at 832 Rishi Nagar, Near Krishna Mandir, Rani Bagh, Delhi-110034, comprised of Ground + 03 upper floors has already been issued FSC by this department vide letter No. F.6/DFS/MS/School/WZ/2022/706 dated 24.06.2022. The premises was re-inspected by the officer concerned of this department on 13.10.2025 in the presence of Mr. Krishan Gopal Suri and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class Group B "Educational" with effect from 31/10/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 31/10/2025 at New Delhi by

  
(S. K. Dua)

Dy. Chief Fire Officer (WZ)  
Delhi Fire Service

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, Om Public School, located at 832 Rishi Nagar, Near Krishna Mandir, Rani Bagh, Delhi-110034.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

[http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/) [http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)



**INSPECTION REPORT**

1. Name & address of the building	Om Public School, located at 832 Rishi Nagar, Near Krishna Mandir, Rani Bagh, Delhi-110034.			
2. Type of Occupancy	Educational			
3. Type of Case	Renewal ( <b>Ground + 03 upper floors</b> )			
4. Details of Previous NOC	F.6/DFS/Ms/School/WZ/2022/706 dated 24.06.2022.			
5. Fire Safety directives letter No	262-362 dated 17.01.2005 & NBC Part-IV			
6. Date of inspection	13.10.2025			
7. Name of Inspecting Officer	Sh. Ajay Kumar Sharma ADO (Wazirpur/MN)			
8. Name and designation of officers From the building side	Mr. Krishan Gopal Suri			
9. Year of Construction	1996 (As per previous inspection report dated 13.06.2022)			
10. Applicant's letter No.	Online e-mail dated 06.09.2025			
S. No	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	Accessible	Accessible	MR(Old case)
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	<b>a. Number of staircases</b>			
	• Upper Floors	01nos.	02nos.	MR
	• Basements	-NA-	-NA-	-NA-
	<b>b. Width of staircases</b>			
	• Upper Floor	1.5m	1m & 0.63m	MR(Old case)
	• Basements	-NA-	-NA-	-NA-
	<b>c. Protection of exits</b>			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	<b>d. No. of continuous staircases to terrace</b>	01nos.	Provided	MR
	<b>e. Width of Corridor</b>	-NA-	-NA-	-NA-
	<b>f. Door Size</b>	1m	0.90m	MR (Old case)
3.	<b>Compartmentation</b>			
	a) Fire check door	-NA-	-NA-	-NA-
	b) Sealing of electrical shafts	-NA-	-NA-	-NA-
	c) Fire Rating of shaft door	-NA-	-NA-	-NA-
	d) Water Curtain	-NA-	-NA-	-NA-
	e) Fire Dampers	-NA-	-NA-	-NA-
4.	<b>Smoke Management System</b>			
	a) Basements	-NA-	-NA-	-NA-
	b) Upper floors	-NA-	-NA-	-NA-
5.	<b>Fire Extinguishers</b>			
	a) Total numbers	08nos.	Provided	MR
	b) Types	ABC/CO2	ABC/CO2	MR
	c) IS marking	ISI marked	Yes	MR
6.	<b>First-Aid Hose Reels</b>			
	a) Total numbers on each floor	01nos.	Provided	MR
	b) Length of hose reel hose	30mm	Provided	MR
	c) Nozzle diameter	5m	Provided	MR



7.	<b>Automatic fire detection and alarming system</b>			
	a) Type of detectors	-NA-	-NA-	-NA-
	b) Location of Main Panel	-NA-	-NA-	-NA-
	c) Location of Repeater Panel	-NA-	-NA-	-NA-
	d) Alternate source of power	-NA-	-NA-	-NA-
	e) Hooters' Location	-NA-	-NA-	-NA-
8.	<b>MOEFA</b>	-NA-	-NA-	-NA-
9.	<b>Public Address System</b>	-NA-	-NA-	-NA-
10.	<b>Automatic Sprinkler System</b>			
	a) Basement	-NA-	-NA-	-NA-
	b) Ground & Upper Floors	-NA-	-NA-	-NA-
	c) Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	<b>Internal Hydrants</b>			
	a) Size of riser/down-comer	-NA-	-NA-	-NA-
	b) Number of hydrants per floor	-NA-	-NA-	-NA-
	c) Hose Box	-NA-	-NA-	-NA-
12.	<b>Yard Hydrants</b>			
	a) Total number of hydrants	-NA-	-NA-	-NA-
	b) Hose Box	-NA-	-NA-	-NA-
13.	<b>Pumping Arrangements</b>			
	• Ground Level			
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	Terrace level			
	➤ Discharge of pump	450lpm & 180lpm	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	Provided	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	5,000ltr	Provided	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	a) Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	b) Pressurization of Lift lobby	-NA-	-NA-	-NA-
	c) Communication In lift Car	-NA-	-NA-	-NA-
	d) Fireman's Grounding Switch	-NA-	-NA-	-NA-
	e) Lift Signage	-NA-	-NA-	-NA-
17.	<b>Standby power supply</b>	-NA-	-NA-	-NA-

## Refuge Area.

a)	Total Area	-NA-	-NA-	-NA-
b)	Location	-NA-	-NA-	-NA-
19.	Fire Control Room			
a)	Detector System Panel	-NA-	-NA-	-NA-
b)	Flow Switch Panel	-NA-	-NA-	-NA-
c)	PA System Panel	-NA-	-NA-	-NA-
d)	Battery backup	-NA-	-NA-	-NA-
e)	Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4, and removal of shortcomings issued vide letter no. 620 dated 07.08.2025, the FSC issued vide letter no. F.6/DFS/MS/School/WZ/2022/706 dated 24.06.2022, renewal of FSC under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Signature of the Inspecting Officer  
Name Ajay Kumar Sharma  
Designation ADO(Wazirpur/MN)

DO(W)

*[Signature]*  
Principal Director

*[Signature]*  
15/10/25

By. CFO to Issue.

*[Signature]*  
By. CFO (WZ)

*[Signature]*  
17/10/25  
*[Signature]*  
21/10/25

*[Signature]*  
ADO (WZ)

FI letter to put up for kind  
perusal and signature please.

*[Signature]*  
Deputy

*[Signature]*  
17/10/25

*[Signature]*  
28/10/25