



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F6/DFS/MS/2025/School/ 27

Dated: 13/01/2025

To,
The Principal,
O.P. Suri Memorial Society (The Srijan School)
Plot No. 4B, North Model Town, Delhi-09.

Sub: - Regarding renewal of fire safety certificate in r/o O.P Suri Memorial Society (The Srijan School) located at Plot No. 4B, North Model Town, Delhi-110009.

Sir,
Please refer to your letter received through online e-mail dated: 23.12.2024 on the subject cited above. In this connection this is to inform you the aforesaid building was inspected by the officers concerned of this department on 08.01.2025 in the presence of Mr. Devashish Tiwari (Admin Officer) to verify the status of the shortcomings already issued by this department vide letter No.F6/DFS/MS/2024/School/771 dated 14.11.2024 and status is as under: -

S No.	Shortcomings	Status
1.	Fire check doors found removed at some places.	Not Complied
2.	Hose reel hose is provided but not functional.	Complied
3.	Internal hydrant is provided but not functional.	Complied
4.	Terrace level fire pump capacity of 900lpm is provided but not functional.	Complied
5.	Terrace level fire water tank capacity of 20,000ltr is provided and 5,000ltr water tank found removed at site.	Not Complied
6.	Exit, floor & lift signage's found removed at strategic locations in the school building.	Complied
7.	Electrical panel below in staircase needs to be removed/shifted in a safer place.	Complied
8.	Two staircases from ground to terrace level found obstruct by combustible old damaged furniture material/ highly flammable & risk of life needs to be removed.	Complied

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Dy. Director of Education, Zone-IX, District North West-A, Shalimar Bagh, BL Block, Delhi- 110088.