



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/Hospital/2025/SZ/ 230

Dated: 06/05/2025

**FIRE SAFETY CERTIFICATE**

Certified that main **OPD Block** located at Safdarjung Hospital complex, Ring Road, New Delhi-110029, comprised of **ground plus 05 upper floors**, owned/occupied by Ministry of Health, Govt of India, was issued **FSC** by this department vide letter No. F6/DFS/MS/Hospital/SZ/2021/587 dated 26/11/2021. The premise was re-inspected by the officer concerned of this department on dated 26/04/2025 in the presence of Sh. A.K. Singh, AE (Elect.) and found that the said premises have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the said building/premises is fit for occupancy class "**Institutional, Group-C**" (Hospital) with effect from 06/05/2025 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010.

Issued on 06/05/2025 at New Delhi by

(ATUL GARG)  
 DIRECTOR  
 Ph. 011-23414000

Copy to: -

1. The Executive Engineer (Elect), SJHED, Central Public Works Department, Safdarjung Hospital Complex, Ring Road, New Delhi-110029
2. The Medical Superintendent, Safdarjung Hospital, Ring Road, New Delhi-110029

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
5. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, prior to its expiry.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)



INSPECTION REPORT				
1	Name & Address of the Building	OPD Block, Safdarjung Hospital Complex, Ring Road, New Delhi-110029		
2	Type of Occupancy	Institutional Building "C" (Hospital)		
3	Building Comprised of	Ground plus 05 upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/Hospital/SZ/2021/587 dated 26/11/2021		
6	Fire Safety Directives Letter No	F6/MS/DFS/88/1655 dated 10/11/1988 & F6/MS/DFS/BP/Hospital/2001/1486 Dt. 27/07/2001		
7	Date of Inspection	26/04/2025		
8	Name of the Inspecting Officers	ADO (SJ)		
9	Name & Designation of Officers from the building side	Sh. A.K Singh, AE (Elect.)		
10	Year of construction	1991 & 2005		
11	Applicant letter No.	Through Outdoor Diary No. 297 dated 07/04/2025		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirement U/R 35(6)	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	9 mtr	12 mtr	MR
	• Gate width	5 mtr	5 mtr	MR
	• Width of internal road	6 mtr	6 mtr on two side only	MR (Old case)
2	Number, width, type and arrangements of exits.			
	a. Number of Staircase			
	➤ Upper floors	5 & 1 (Ramp)	5 & 1 (Ramp)	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	b. Width of Staircase			
	➤ Upper floors	2m (each)	1.8 mtr (each) and ramp- 2.20m	MR (Old case)
	➤ Basement floor	-NA-	-NA-	-NA-
	c. Protection of exits			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircase to terrace	5 & 1 (Ramp)	5 & 1 (Ramp)	MR
	e. Width of corridor	2.4m	2.4m	MR
	f. Door size	2m/1.5m/1m	2m/1.5m/1m	MR
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	Required	Provided	MR
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers.			
	• Total numbers	96 Nos	Provided	MR
	• Types	ABC / CO <sub>2</sub>	ABC & CO <sub>2</sub>	MR
	• ISI Marking	Required	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	8 Nos	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR



N-21

7	<b>Automatic Fire Detection and Alarming system.</b>			
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	Ground floor	Ground floor	MR
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	All Areas	Provided	MR
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	Required	Provided	MR
10.	<b>Automatic Sprinkler System</b>			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	<b>Internal Hydrants.</b>			
	• Size of Riser / Down-comer	100 mm	Provided	MR
	• Number of Hydrant per floor	8 Nos	Provided	MR
	• Hose box.	8 Nos	Provided	MR
12.	<b>Yard Hydrants.</b>			
	• Total number of hydrants.	10 Nos.	Provided	MR
	• Hose box.	10 Nos.	Provided	MR
13.	<b>Pumping arrangements.</b>			
	• <b>Ground Level</b>	Common firefighting system for entire complex		
	➤ Discharge of main pump.	2850 LPM	2850 LPM	MR
	➤ Head of main pump.	90m	70m	MR
	➤ Number of main pumps.	One	One	MR
	➤ Jockey Pump output.	220 LPM	250 LPM	MR
	➤ Jockey Pump head.	90m	70m	MR
	➤ Standby Pump output.	2850 LPM	2850 LPM	MR
	➤ Standby Pump head.	90m	70m	MR
	➤ Auto Starting/Manual Stopping.	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• <b>Terrace Level</b>			
	➤ Discharge of pump.	-NA-	-NA-	-NA-
	➤ Head of pump.	-NA-	-NA-	-NA-
	➤ Power supply.	-NA-	-NA-	-NA-
	➤ Auto starting of pump.	-NA-	-NA-	-NA-
14.	<b>Captive water storage for firefighting.</b>			
	• Underground tank capacity.	2,00,000 Ltr	Provided	MR
	➤ Draw-off connection.	Required	Provided	MR
	➤ Fire Service Inlet.	Required	Provided	MR
	➤ Access to tank.	Required	Provided	MR
	• Overhead tank capacity.	-NA-	-NA-	-NA-
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	Required	Provided	MR
	• Fireman's switch.	Required	Provided	MR
	• Lift signage.	Required	Provided	MR
17	<b>Standby Power Supply</b>	Required	Provided	MR
18.	<b>Refuge Area</b>			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-

82

N-22

19.	Fire Control Room.	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Detector system panel.</li> <li>• Flow switch panel.</li> <li>• PA system panel.</li> <li>• Battery backup</li> <li>• Building floor plan</li> </ul>	-NA-	-NA-	-NA-
		Required	Provided	MR
		Required	Provided	MR
		-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risk, if any.	Required	CO <sub>2</sub> & ABC fire extinguishers provided near LT & HT Panel	MR

The fire protection systems provided in the premises/building were checked, tested at random and found functional at the time of inspection. The shortcomings issued vide letter No. F.6/DFS/MS/Hospital/2025/SZ/125 dated 26/03/2025 found rectified.

In view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/Hospital/SZ/2021/587 dated 26/11/2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for perusal/approval & signature please.

*[Signature]*  
30/04/25  
Signature of the Inspecting Officer  
Name: Santosh Kumar  
Designation: ADO (SJ)

DO (SD) *[Signature]*

AO (RUB) *[Signature]*  
25/5/2025

Director *[Signature]*  
2/5/25

*[Signature]*

Sir,  
F-T letter is put up for your sing. pl

Director *[Signature]*  
C/S/1

*[Signature]*  
05/05/25

✓