

c/9

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/2025/ 977

Dated: 11/06/2025

To

Dr. Kartik K Raman ,
Senior medical Officer
Link Officer , Fire and Safety
LHMC & Smt. S.K Hospital,
New Delhi.

Sub: Regarding issuance of FSC in r/o OPD, IPD and A& E block at at Lady Harding Medical College and associated Hospital, at Shaheed Bhagat Singh Marg, New Delhi .

Sir,

This has a reference to letter no. LHMC/A.C.V/2025/171 dated 23.05.2025, on the subject cited above. In this regards it is to inform you that the site was inspected by officers of this department on 04/06/2025 in the presence of Dr. Arvind & Schin. JE and the following shortcomings were observed:

1. Smoke management system found nonfunctional and also not integrated with alarm system.
2. Detectors found nonfunctional.
3. MOEFA found nonfunctional.
4. PA system found nonfunctional.
5. Fireman's switch found nonfunctional.
6. Pressurization system of staircases, lift lobby and lift shaft found nonfunctional.

In view of above shortcomings, the application of issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at risk and liability of owner/occupier. The licensing /statuary authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:

1. The Chief Architect, NDMC, Palika Kendra, New Delhi.
2. AE, Elec., CPWD, Lady Harding Medical College & Associated Hospital, New Delhi.