



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/ 45

Dated: 17/01/2025

To

Authorized Signatory,
OPG World School, Sector-19B, Dwarka,
New Delhi-110075

Sub: Reg. Issuance of Fire Safety Certificate in respect of OPG World School located at Sector-19B, Dwarka, New Delhi-110075

Sir,

This has reference to your letter received through outdoor diary No. 10626 dated 23.12.2024, on the subject cited above. In this connection, it is to inform you that the said premise was visited by the officer concerned of this department on 03/01/2025 in the presence of Mr. Subhash Pandey (Estate Manager) from fire safety and means of escape point of view. During the inspection, the shortcomings observed are as below.

1. Fire check doors not found provided.
2. Smoke management system not integrated with MOEFA in basement.
3. Manually operated electric fire alarm system (MOEFA) found non-functional.
4. Public address system found non-functional.
5. Internal & yard hydrants found non-functional.
6. Main pump & standby pump of 2280 LPM, Jockey pump of 180 LPM at ground level found non-functional.
7. Terrace fire pump of 900 LPM found non-functional.
8. Dimensions of underground water storage tank of 200,000 liters and terrace tank of 25,000 liter not yet provided.
9. Exit signage not provided at some places.
10. Pressurization in lift shaft found non-functional.
11. PA system panel, battery backup & building floor plan not provided in school fire control room.

In view of the above, the application for issuance of fire safety certificate is rejected. You are requested to rectify the shortcomings above under intimation to this department for further action. The occupancy of the premise/building in the absence of requisite fire safety arrangement shall be at the risk and responsibility of school management.

Yours faithfully,

(ATUL GARG)
DIRECTOR

T. No. 011-23414000

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054