



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F.6/DFS/MS/School/2025/NDZ/ 319

Dated 02/05/2025

To,

The Manager,
Oriental Modern Public School
V-497, Arvind Nagar, Ghonda,
Delhi-110053.

Sub:- Regarding Renewal of Fire Safety Certificate r/o Oriental Modern Public School at V-497, Arvind Nagar, Ghonda, Delhi-110053.

Sir,

With reference to your letter no. nil dated 24/03/2025 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection on dated 22/04/2025 of the above mentioned School from fire safety point of view in presence of the Sh. Raja Ram Dhama (Manager). The building comprised of ground plus two upper floors but school is running ground and first floor only & 2nd floor lying vacant. Following shortcomings were observed during the time of inspection.

1. An additional staircase of width 01 meter found removed.
2. First Aid Hose reels found removed.
3. A terrace pump 220 lpm head 40 meters not provided..
4. An overhead tank capacity 2,500 liter not provided.

In view of the above, the building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to rectify the above mentioned shortcomings under intimation to this office for further course of action.

Yours faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

The Dy. Director of Education,
B-Block Yamuna Vihar, Delhi- 110053