

c/04

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

No.F6/DFS/MS/NDZ/School/2025/ 272  
To

Dated: 23/04/2025

The Principal,  
Orion Public School,  
2561, Ram Richpal Street,  
Choori Walan, Delhi - 110006.

**Sub: - Regarding issuance of "Fire Safety Certificate" from fire safety point of view in r/o Orion Public School, 2561, Ram Richpal Street, Choori Walan, Delhi - 110006.**

Sir,

This has reference to letter No. OPS/2025/463 dated 20.03.2025 received in this department, on the subject cited above. In this connection, this is to inform you that the school building was visited by the officer concerned from this department on 17.04.2025 in the presence of Mr. Junaid Ahmad (Principal) and observed that the building is comprised of ground + 03 upper floors and have complied the shortcomings issued vide letter no. F6/DFS/MS/School/NDZ/2020/140 dated 13.02.2020 except following which still exists.

1. The school is not accessible to fire engines as approach road width is less than 06 mtrs.
2. One more staircase is required from 1<sup>st</sup> floor to 3<sup>rd</sup> floor having width not less than 0.75 m.
3. First aid hose reels not provided at each floor.
4. Fire pump having capacity 450 LPM out put with 40 m head not provided.
5. Over head water storage tank of 10,000 ltrs. capacity is required exclusively for firefighting.

In view of the above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management.

Yours faithfully,

  
(Atul Garg)

Director o/c

Delhi Fire Service

Tel: 011-23414000

**Copy to:-**

The Director of Education,  
Govt. of NCT of Delhi, Old Secretariat, Delhi.