

C/8

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

No.F6/DFS/MS/NDZ/School/2025/ 570

Dated: 03/07/2025

To

The Principal,  
Sharda Devi Sanskrit Vidyapeeth,  
Darya Ganj, Delhi - 110006.

**Sub: - Regarding issuance of "Fire Safety Certificate" from fire safety point of view in r/o Orion Public School, 2561, Ram Richpal Street, Choori Walan, Delhi - 110006.**

Sir,

This has reference to your letter No. SDS/2025/395 dated 18.06.2025 received in this department on the subject cited above. In this connection, this is to inform you that the school building was visited by the officer concerned from this department on 30.06.2025 in the presence of Mr. Rajkumar (Security Guard) and observed that the building is comprised of ground + 04 upper floors, ground floor (temple), 1<sup>st</sup> floor (other office), 2<sup>nd</sup> floor (classroom + hostels), 3<sup>rd</sup> & 4<sup>th</sup> floor (class room). During inspection following shortcomings were observed:

1. The school is not accessible to fire engines as approach road width is less than 06 mtrs.
2. First aid hose reel provided but not functional.
3. Fire pump provided but not functional.

In view of the above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management.

Yours faithfully,

  
(Atul Garg)  
Director

Delhi Fire Service  
Tel: 011-23414000

01/07/25  
8/16/17

**Copy to:-**

The Director of Education,  
Govt. of NCT of Delhi, Old Secretariat, Delhi.