



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/ 478

Dated: 06/06/2025

To

Smt. Sunita Kant (H.O.S)
Oscar Public School located at
Kaushik Enclave, Swaroop Nagar, Delhi-86.

Sub: - Regarding renewal of fire safety certificate in r/o Oscar Public School located at Kaushik Enclave, Swaroop Nagar, Delhi-110086.

Sir,

Please refer to your letter No- OPS/FIRE/2025-26/05 dated 09/05/2025 & Online e-mail dated 04/06/2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 26/05/2025 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of 03 blocks, 02 blocks comprised of ground & first floor each and 01 block comprised of ground floor only. At the time of inspection Smt. Sunita Kant (H.O.S) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. Staircases leading to terrace must be cleared from combustible wooden furniture above first floor.
2. A- Block an alternate staircase is locked at the time of inspection needs to be open during the school timing in case of emergency.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully

(M.K. Chattopadhyay)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Deputy Director of Education, GNCT of Delhi, Zone-VII, District North Lucknow Road, Timarpur, Delhi - 110054.