

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/2025/SZ/ 439

Dated: 03/09 /2025

To

Sh. Anil Kapoor (Partner), M/s Kapoor Sons & Co., Ground Floor, 112-113, Gautam Nagar, New Delhi-110049

Sub: Renewal of Fire Safety Certificate in r/o Building located at Property No. 112–113, Gautam Nagar, New Delhi–110029.

Sir,

This is with reference to your letter No. Nil dated 11/07/2025 received in this department vide outdoor diary No. 3682 dated 11/07/2025 regarding compliance of shortcomings earlier communicated vide letter No. F.6/DFS/MS/2025/SZ/285 dated 16/06/2025. In this connection, it is to inform you that the said premises was re-inspected by the concerned officers of this department on 05/08/2025 in the presence of Mr. Amit Rajput to verify the compliance of shortcomings earlier communicated vide above referred letter. During course of inspection, the shortcomings observed is as below.

- 1. 6-meter-wide road around the building found encroached/blocked.
- 2. Hose-reel, hydrant & sprinklers found partially functional.
- 3. Basement is used for grocery outlet (sale & storage) & coaching center with blocked/insufficient entry/exit/escape in the event of an incident.
- 4. Standby diesel pump found non-functional.
- 5. Inadequate fresh air in pump house.
- 6. Coaching Centre of DAMS FMGE running at 2nd floor.
- 7. Restaurant still running at stilt floor.

In view of the above shortcomings, renewal of fire safety certificate cannot be considered at this stage & rejected. You are directed to rectify the above-mentioned shortcomings without further delay, otherwise; suitable necessary action under Delhi Fire Service Act & Rules, 2010 shall be initiated including disconnection of electricity and water supply.

Yours faithfully,

(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Dy. Commissioner, Municipal Corporation of Delhi, South Zone, Aurobindo Marg, Green Park, New Delhi-110016with the request to take necessary action.

2. The Dy. Commissioner of Police (South District), Adjacent Hauz Khas Police Station, Ch. Daleep Singh Marg, New Delhi-110016------for information & necessary action.