

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F.6/DFS/MS/2025/ 70

Dated 19.02.2025

To,

The Assistant Engineer (E)-I,
Parliament Annexe Electrical Works Division CPWD,
Parliament Annexe Extension Building, New Delhi.

Sub:- Regarding Fire Safety audit of Parliament House Annexe Building, New Delhi.

Sir,

This has reference to your letter no.23(4)/PAEWD/2025/08/ dated 04.01.2025, on the subject cited above. In this connection, it is to inform that the Parliament House Annexe Building (lower ground, Basement, ground and six upper floor) was inspected by the officers concerned of this department on 04/02/2025 in the presence of Mr. Satayvir Singh , AE & Mr. Vikram , work assistant and the following shortcomings were observed:

1. Fire check doors are not properly closed & door closer is also not provided at some doors .
2. Detectors are provided partially same are required to be extended in left out area and some were found nonfunctional.
3. Electrical shaft not sealed properly .
4. Some fire extinguishers found empty and nozzle/horn of some CO2 fire extinguishers found missing.
5. Hose reels & hydrants are not covering entire area at lower ground/basement, first and second floor, required to be extended to left out area .
6. Sprinklers are required to be extended in left out area at lower ground /basement (medical center)
7. Smoke venting arrangements are not provided at basement and upper floors.
8. PA system found non functional.
9. All wooden partitions at 6th floor required to be painted with FRP & 5th floor is not provided with firefighting system as same was found under renovation.
10. Sanctioned building plan/ as built building if any of the said premises is also required to be submitted to ascertain the year of construction & height of building .

In view of above shortcomings, the fire safety certificate FSC cannot be issued till the compliance of the above shortcomings.

Yours faithfully

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:

1. The Chairman, NDMC, Palika Kendra, New Delhi.
2. The Joint Security, Parliament house complex, New Delhi.
3. The Director , (Estate & Heritage management branch), Parliament House Annex Building , New Delhi
4. The Executive Engineer (E), CPWD, Parliament Annexe Extension Building, New Delhi.