



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

CH



No: F.6/DFS/MS/School/2025/WZ/ 348

Dated: 07/05/2025

To,

The Principal,
Parvati Modern Public School,
Main Saboli Road, Rajeev Colony,
Narela, Delhi-110040.

Sub: - Regarding issuance of Fire Safety Certificate in r/o Parvati Modern Public School, Main Saboli Road, Rajeev Colony, Narela, Delhi-110040.

Sir,

This has reference to your letter no. PMPS/AB2025/01 dated 10/04/2025 received through outdoor diary no. 616 dated 15.04.2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by the officer concerned of this department on 29.04.2025 to see the compliance of shortcomings issued vide letter no. F6/DFS/MS/School/2023/WZ/329 dated 26/06/2023. Smt. Parwati Tiwari was present at the time of inspection.

During the course of inspection it was observed that school building comprised of Two Blocks of Ground Floor only. Your request for issuance of FSC is rejected due to the following shortcomings:-

1. Door width provided 1 m against the required width of 1.20 m.
2. Fire Extinguishers found provided but not functional.
3. ELCB at electric circuit not provided

You are advised to rectify the above-mentioned shortcoming under intimation to this department.

Yours Faithfully

(Atul Garg)
Director
Ph. 011-23414000

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.