



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/WZ/2025/ 710
To,

Dated: 09/09/2025

The Principal,
Parvati Modern Public School,
Main Saboli Road, Rajeev Colony,
Narela, Delhi-110040.

Sub: - Regarding issuance of Fire Safety Certificate in r/o Parvati Modern Public School, Main Saboli Road, Rajeev Colony, Narela, Delhi-110040.

Madam,


This has reference to your letter No. PMPS/July 2025/07 dated 28/07/2025 received through outdoor diary no. 4347 dated 30/07/2025 on the subject cited above. In this connection, it is to inform you that the above said school building was re-inspected by the officer concerned of this department on 21/08/2025 in the presence of Smt. Parwati Tiwari (Principal) to verify the compliance of shortcomings communicated vide this department letter No. F6/DFS/MS/School/2025/WZ/348 dated 07/05/2025 and found that shortcomings mentioned at serial number 2 & 3 are rectified.

The status of shortcoming is as under:-

Sr. No.	Shortcomings	Status
1.	Door width provided 1 m against the required width of 1.20 m.	Not Rectified

In view of the above shortcomings, the request for issuance of Fire Safety Certificate can't be considered at this stage & rejected. You are advised to rectify the above mentioned shortcomings under intimation to this department for further necessary action in this regard.

Yours faithfully,


21/9/2025
(Virendra Singh)
Chief Fire Officer


Copy to:-

1. The Director, Education, Government of NCT of Delhi. Old Sect. Delhi-110054.