



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/2026/WZ/BNQT/ 476

Dated: 18/05/2026

FIRE SAFETY CERTIFICATE

Certified that the PD Area with name M/s S. R Royal Kingdom, (A unit of Induction Corporate Solutions Pvt. Ltd. Ground floor, Haiderpur Badli More Metro Station, Shalimar Bagh, Delhi-110088, in the building comprised of ground level + concourse level + platform level, phase-3, PD area I & II is running at ground floor only has already been issued FSC by this department vide letter No. F.6/DFS/MS/Banquet/WZ/2023/14 dated 20.03.2023. The premises was re-inspected by the team of officers concerned of this department on 01.05.2026 in the presence of Mr. Dhiraj Gupta (Owner) and found that the said mixed occupancy in metro station building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class "Mixed occupancy" (Group-D&F) for ground floor only with effect from 18/05/2026 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 18/05/2026 at New Delhi by


 18/05/26
 (S. K. Dua)

Chief Fire Officer
 Delhi Fire Service

Copy to: -

1. The Commissioner, MCD, Civic centre, New Delhi: to kindly ensure the occupancy as detailed above and deviation in construction if any:
2. The Authorized Signatory, M/s S. R Royal Kingdom, (A unit of Induction Corporate Solutions Pvt. Ltd. Ground floor, Haiderpur Badli More Metro Station, Shalimar Bagh, Delhi-110088.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building		M/s S. R Royal Kingdom, (A unit of Induction Corporate Solutions Pvt. Ltd. Ground floor, Haiderpur Badli More Metro Station, Shalimar Bagh, Delhi-110088.		
2. Type of Occupancy		Mixed (Mercantile & Assembly)		
3. Comprised of building		Ground level + concourse level + platform level, phase-3, PD area I & II		
4. Type of Case		Renewal of PD Area running as S. R Royal Kingdom running at ground floor only		
5. Details of Previous NOC		F.6/DFS/MS/Banquet/WZ/2023/14 dated 20.03.2023.		
6. Fire Safety directives letter No		F.6/DFS/MS/BP/2022/303 dated 28.06.2022.		
7. Date of inspection		01.5.2026		
8. Name of Inspecting Officer		DO (WD) & ADO (Wazirpur)		
9. Name and designation of officers From the building side		Mr. Dhiraj Gupta (Owner)		
10. Year of Construction		2005 pervious inspection report		
11. Applicant's letter No.		Online e-mail dated 17.04.2026.		

S. No	Minimum Standards on fire prevention and fire safety U/R 33	UBBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building (Badli Mor Elevated Metro Station, issued FSC No.F.6/DFS/MS/2025/WZ/110 dated 10.03.2025)			
	• Road width	12m	30m	MR
	• Gate width	Accessible	Accessible	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits [Provided & Maintained by Metro Station]			
	d. Number of staircases			-NA-
	• Upper Floors	-NA-	-NA-	-NA-
	• Basements	-NA-	-NA-	-NA-
	e. Width of staircases			-NA-
	• Upper Floor	-NA-	-NA-	-NA-
	• Basements	-NA-	-NA-	-NA-
	f. Protection of exits	[Provided & Maintained by Metro Station]		
	• Fire check door	Required in kitchen	Provided	MR
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	-NA-	-NA-	-NA-
	e. Width of Corridor	2m & 1.5m	Provided	MR
	f. Door Size			
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	-NA-	-NA-	-NA-
	• Fire Rating of shaft door	-NA-	-NA-	-NA-
	• Water Curtain	-NA-	-NA-	-NA-
	• Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System [Provided & Maintained by Metro Station]			
	a) Basements	-NA-	-NA-	-NA-
	b) Upper floors	Mechanical/Natural ventilation	Exhaust fan provided	MR
5.	Fire Extinguishers			
	• Total numbers	07nos.	Provided	MR

4/10

	• Types	ABC/CO2	ABC/CO2	MR
	• IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reel	[Provided & Maintained by Metro Station]		
	• Total numbers on each floor	02 nos.	Provided	MR
	• Length of hose reel hose	30mm	Provided	MR
	• Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system	[Provided & Maintained by Metro Station]		
	a) Type of detectors	Required	Provided	MR
	b) Location of Main Panel	-NA-	-NA-	-NA-
	c) Location of Repeater Panel	-NA-	-NA-	-NA-
	d) Alternate source of power	-NA-	-NA-	-NA-
	e) Hooters' Location	-NA-	-NA-	-NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System	[Provided & Maintained by Metro Station]		
	• Basement	-NA-	-NA-	-NA-
	• Ground & Upper Floors	-NA-	Provided by Metro Station	-NA-
	• Sprinkler above false ceiling	-NA-	Provided by Metro Station	-NA-
11.	Internal Hydrants			
	• Size of riser/down-comer	-NA-	Provided by Metro Station	-NA-
	• Number of hydrants per floor	-NA-	Provided by Metro Station	-NA-
	• Hose Box	-NA-	Provided by Metro Station	-NA-
12.	Yard Hydrants	[Provided & Maintained by Metro station]		
	• Total number of hydrants	-NA-	Provided by Metro Station	-NA-
	• Hose Box	-NA-	Provided by Metro Station	-NA-
13.	Pumping Arrangements	[Provided & Maintained by Metro station]		
	• Ground Level			
	➤ Discharge of main Pump	-NA-	2 x 2280lpm	-NA-
	➤ Head of Main pump	-NA-	80m	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	2 x 180lpm	-NA-
	➤ Jockey pump head	-NA-	80m	-NA-
	➤ Standby Pump out put	-NA-	2280lpm	-NA-
	➤ Standby Pump Head	-NA-	80m	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	Provided	-NA-
	➤ Pump House Access	-NA-	Provided	-NA-
	Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14.	Captive Water Storage for fire fighting	[Provided & Maintained by Metro Station]		
	• Underground tank capacity	NA	2,00,000ltr	MR

➤ Draw-off connection	NA	Provided by Metro station	MR
➤ Fire service inlet	NA	Provided by Metro station	MR
➤ Access to tank	NA	Provided by Metro station	MR
• Overhead Tank capacity	10,000ltr	15,000Ltrs provided by metro	MR
15. Exit Signage.	Required	Provided	MR
16. Provision of Lifts.	[Provided & Maintained by Metro Station]		
• Pressurization of Lift Shaft	-NA-	-NA-	-NA-
• Pressurization of Lift lobby	-NA-	-NA-	-NA-
• Communication In lift Car	-NA-	-NA-	-NA-
• Fireman's Grounding Switch	-NA-	-NA-	-NA-
• Lift Signage	-NA-	-NA-	-NA-
17. Standby power supply	Required	Provided	MR
18. Refuge Area.	[Provided & Maintained by Metro Station]		
➤ Total Area	-NA-	-NA-	-NA-
➤ Location	-NA-	-NA-	-NA-
19. Fire Control Room	-NA-	-NA-	-NA-
• Detector System Panel	-NA-	-NA-	-NA-
• Flow Switch Panel	-NA-	-NA-	-NA-
• PA System Panel	-NA-	-NA-	-NA-
• Battery backup	-NA-	-NA-	-NA-
• Building Floor Plans	-NA-	-NA-	-NA-
20. Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F.6/DFS/MS/Banquet/WZ/2023/14 dated 20.03.2023 is recommended for renewal of FSC under rule 37 of the Delhi Fire Service rules 2010.

Signature of the Inspecting Office

Name: - Rajesh Kumar
Designation:- DO/West

Signature of the Inspecting Officer

Name: - Ajay Kumar Sharma
Designation:- ADO (Wazirpur)

CFolwz

KVP 11/05/26

Pr. Director

CFD to Issue.

12/05/26

CFD (WZ)

F.T. please.

ADO (WZ)

KVP 14/05/26

As letter is put up for kind perusal and signature please

CFD

KVP 18/05/26

15/5/26